

# 屋内照明器具特性

品番 (品名)	XAD3 1 8 1 2		
光源	LLD4 0 4 0 2 C Q 1 ( SHUKOU ) × 1          6 2 0 . 0 1 m		
管理番号	K 0 1 8 3 9 4 6 ( 0 ) D R 1		
B Z 分類	B Z 1		

器具効率	94 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束 0 %		反射率	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	94 %	床		10 %				10 %				10 %				10 %				0 %
室指数	照明率 ( X 0 . 0 1 )																			Z C M
保守率	良	0.67	0.6	73	67	62	59	73	66	62	59	71	66	62	59	70	65	62	59	58
	中	0.63	0.8	81	75	70	68	80	74	70	67	78	73	70	67	77	72	69	67	66
	否	0.56	1.0	85	79	76	73	84	79	75	73	82	78	75	72	81	77	74	72	71
下方投影面積	等価発光面積	cm <sup>2</sup>	1.25	88	84	80	77	87	83	80	77	85	82	79	77	84	81	78	76	75
			1.5	90	86	83	81	89	86	83	80	88	84	82	80	86	83	81	79	78
取付高さ	器具間隔最大限		2.5	95	92	90	88	94	91	89	87	92	90	88	86	90	88	87	86	84
	横方向 ( A )	縦方向 ( B )	3.0	96	94	92	90	95	93	91	89	93	91	90	88	91	90	88	87	85
H m	0.74 H m	0.74 H m	4.0	97	96	94	92	96	95	93	92	94	93	92	91	92	91	90	89	87
			5.0	98	97	95	94	97	96	94	93	95	94	93	92	93	92	91	91	91
			7.0	99	98	97	96	98	97	96	95	96	95	94	94	94	93	93	92	90
			10.0	100	99	98	97	99	98	97	97	97	96	95	95	95	94	94	93	91

