

# 屋内照明器具特性

|         |                           |                 |
|---------|---------------------------|-----------------|
| 品番 (品名) | XAD5 1 2 0 V              |                 |
| 光源      | LLD5 0 2 0 VCC1 × 1       | 1 0 8 5 . 0 1 m |
| 管理番号    | K0 1 8 7 6 7 4 ( 2 ) DR 1 |                 |
| B Z 分類  | B Z 1                     |                 |

|        |          |                  |                   |     |     |     |      |     |     |     |      |     |    |    |      |    |    |    |       |     |
|--------|----------|------------------|-------------------|-----|-----|-----|------|-----|-----|-----|------|-----|----|----|------|----|----|----|-------|-----|
| 器具効率   | 97 %     | 天井               | 80 %              |     |     |     | 70 % |     |     |     | 50 % |     |    |    | 30 % |    |    |    | 0 %   |     |
|        | 上方光束     |                  | 0 %               | 70  | 50  | 30  | 10   | 70  | 50  | 30  | 10   | 70  | 50 | 30 | 10   | 70 | 50 | 30 | 10    | 0 % |
| 下方光束   | 97 %     | 床                | 10 %              |     |     |     | 10 % |     |     |     | 10 % |     |    |    | 10 % |    |    |    | 0 %   |     |
| 室指数    |          |                  | 照明率 ( X 0 . 0 1 ) |     |     |     |      |     |     |     |      |     |    |    |      |    |    |    | Z C M |     |
| 保守率    | 良        | 0.67             | 0.6               | 77  | 70  | 65  | 62   | 76  | 69  | 65  | 62   | 74  | 69 | 65 | 62   | 73 | 68 | 65 | 62    | 61  |
|        | 中        | 0.63             | 0.8               | 83  | 77  | 73  | 70   | 82  | 77  | 72  | 70   | 81  | 76 | 72 | 69   | 79 | 75 | 72 | 69    | 68  |
|        | 否        | 0.56             | 1.0               | 87  | 82  | 78  | 75   | 86  | 81  | 77  | 74   | 85  | 80 | 77 | 74   | 83 | 79 | 76 | 74    | 72  |
| 下方投影面積 | 等価発光面積   | c m <sup>2</sup> | 1.25              | 91  | 86  | 82  | 79   | 90  | 85  | 82  | 79   | 88  | 84 | 81 | 78   | 86 | 83 | 80 | 78    | 77  |
|        |          |                  | 1.5               | 93  | 89  | 85  | 83   | 92  | 88  | 85  | 82   | 90  | 87 | 84 | 82   | 88 | 85 | 83 | 81    | 79  |
| 取付高さ   | 器具間隔最大限  |                  | 2.0               | 96  | 92  | 90  | 87   | 95  | 92  | 89  | 87   | 93  | 90 | 88 | 86   | 91 | 89 | 87 | 85    | 83  |
|        | 横方向 (A)  | 縦方向 (B)          | 2.5               | 98  | 95  | 92  | 90   | 97  | 94  | 92  | 90   | 95  | 92 | 90 | 89   | 93 | 91 | 89 | 88    | 86  |
| H m    | 0.45 H m | 0.45 H m         | 3.0               | 99  | 96  | 94  | 92   | 98  | 96  | 93  | 92   | 96  | 94 | 92 | 90   | 94 | 92 | 91 | 89    | 87  |
|        |          |                  | 4.0               | 100 | 98  | 97  | 95   | 99  | 97  | 96  | 94   | 97  | 96 | 94 | 93   | 95 | 94 | 93 | 92    | 90  |
|        |          |                  | 5.0               | 101 | 100 | 98  | 97   | 100 | 99  | 97  | 96   | 98  | 97 | 96 | 95   | 96 | 95 | 94 | 93    | 91  |
|        |          |                  | 7.0               | 102 | 101 | 100 | 99   | 101 | 100 | 99  | 98   | 99  | 98 | 97 | 96   | 97 | 96 | 96 | 95    | 92  |
|        |          |                  | 10.0              | 103 | 102 | 101 | 101  | 102 | 101 | 100 | 100  | 100 | 99 | 99 | 98   | 98 | 97 | 97 | 96    | 94  |

