

# 屋内照明器具特性

|         |                                |  |  |  |  |  |  |  |  |  |
|---------|--------------------------------|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | XND9983SLZ                     |  |  |  |  |  |  |  |  |  |
| 光源      | LED3000_80_12110 ×1 12110.0 1m |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0188509(0)DB1                 |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ1                            |  |  |  |  |  |  |  |  |  |

| 器具効率   | 100%    | 天井              | 80%           |     |     |     | 70% |     |     |     | 50% |     |     |     | 30% |     |     |     | 0%  |    |
|--------|---------|-----------------|---------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|
|        |         |                 | 壁             | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 0% |
| 上方光束   | 0%      | 床               | 10%           |     |     |     | 10% |     |     |     | 10% |     |     |     | 10% |     |     |     | 0%  |    |
| 下方光束   | 100%    | 室指数             | 照明率 ( X0.01 ) |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     | ZCM |    |
| 保守率    | 良       | 0.76            | 0.6           | 74  | 65  | 60  | 56  | 73  | 65  | 60  | 56  | 71  | 64  | 59  | 56  | 69  | 63  | 59  | 56  | 54 |
|        | 中       | 0.72            | 0.8           | 83  | 76  | 71  | 67  | 82  | 75  | 71  | 67  | 80  | 74  | 70  | 67  | 78  | 73  | 70  | 67  | 65 |
|        | 否       | 0.64            | 1.0           | 89  | 82  | 78  | 74  | 88  | 82  | 77  | 74  | 86  | 81  | 77  | 74  | 84  | 79  | 76  | 73  | 72 |
|        |         |                 | 1.25          | 93  | 87  | 83  | 80  | 92  | 87  | 83  | 80  | 90  | 86  | 82  | 79  | 88  | 84  | 81  | 79  | 77 |
| 下方投影面積 |         | cm <sup>2</sup> | 1.5           | 96  | 91  | 87  | 84  | 95  | 90  | 87  | 84  | 92  | 89  | 86  | 83  | 90  | 87  | 85  | 83  | 81 |
| 等価発光面積 |         | cm <sup>2</sup> | 2.0           | 99  | 95  | 92  | 89  | 98  | 94  | 91  | 89  | 96  | 93  | 90  | 88  | 94  | 91  | 89  | 87  | 85 |
| 取付高さ   | 器具間隔最大限 |                 | 2.5           | 101 | 98  | 95  | 93  | 100 | 97  | 94  | 92  | 98  | 95  | 93  | 91  | 96  | 94  | 92  | 90  | 88 |
|        | 横方向 (A) | 縦方向 (B)         | 3.0           | 102 | 100 | 97  | 95  | 101 | 99  | 96  | 94  | 99  | 97  | 95  | 93  | 97  | 95  | 94  | 92  | 90 |
| Hm     | 1.41Hm  | 1.41Hm          | 4.0           | 104 | 102 | 100 | 98  | 103 | 101 | 99  | 97  | 101 | 99  | 97  | 96  | 98  | 97  | 96  | 95  | 92 |
|        |         |                 | 5.0           | 105 | 103 | 102 | 100 | 104 | 102 | 101 | 99  | 101 | 100 | 99  | 98  | 99  | 98  | 97  | 96  | 94 |
|        |         |                 | 7.0           | 106 | 105 | 103 | 102 | 105 | 104 | 103 | 101 | 103 | 102 | 101 | 100 | 100 | 100 | 99  | 98  | 96 |
|        |         |                 | 10.0          | 107 | 106 | 105 | 104 | 106 | 105 | 104 | 103 | 103 | 103 | 102 | 101 | 101 | 101 | 100 | 100 | 97 |

