

# 屋内照明器具特性

|         |                              |  |  |  |  |  |  |  |  |  |
|---------|------------------------------|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | XLX431BSNT_65DEG             |  |  |  |  |  |  |  |  |  |
| 光源      | LED5000_85_2790 x1 2790.0 lm |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0145763 (* ) DB1            |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ5/0.7/BZ4                  |  |  |  |  |  |  |  |  |  |

|        |         |         |               |     |     |     |      |     |     |     |      |     |    |    |      |    |    |    |     |    |
|--------|---------|---------|---------------|-----|-----|-----|------|-----|-----|-----|------|-----|----|----|------|----|----|----|-----|----|
| 器具効率   | 100 %   | 天井      | 80 %          |     |     |     | 70 % |     |     |     | 50 % |     |    |    | 30 % |    |    |    | 0 % |    |
|        |         | 壁       | 70            | 50  | 30  | 10  | 70   | 50  | 30  | 10  | 70   | 50  | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |    |
| 上方光束   | 0 %     | 床       | 10 %          |     |     |     | 10 % |     |     |     | 10 % |     |    |    | 10 % |    |    |    | 0 % |    |
| 下方光束   | 100 %   | 室指数     | 照明率 ( X0.01 ) |     |     |     |      |     |     |     |      |     |    |    |      |    |    |    | ZCM |    |
| 保守率    | 良       | 0.81    | 0.6           | 58  | 46  | 38  | 33   | 57  | 45  | 38  | 33   | 54  | 44 | 38 | 33   | 52 | 43 | 37 | 33  | 31 |
|        | 中       | 0.77    | 0.8           | 68  | 57  | 49  | 44   | 67  | 56  | 49  | 44   | 64  | 55 | 48 | 43   | 61 | 54 | 48 | 43  | 41 |
|        | 否       | 0.68    | 1.0           | 75  | 64  | 57  | 51   | 73  | 64  | 57  | 51   | 70  | 62 | 56 | 51   | 68 | 61 | 55 | 51  | 48 |
|        |         |         | 1.25          | 81  | 71  | 65  | 59   | 79  | 71  | 64  | 59   | 76  | 69 | 63 | 58   | 74 | 67 | 62 | 58  | 56 |
| 下方投影面積 |         |         | 1.5           | 85  | 76  | 70  | 65   | 83  | 76  | 69  | 64   | 80  | 74 | 68 | 64   | 78 | 72 | 67 | 63  | 61 |
|        |         |         | 2.0           | 90  | 83  | 78  | 73   | 89  | 82  | 77  | 73   | 86  | 80 | 76 | 72   | 83 | 78 | 75 | 71  | 69 |
| 取付高さ   | 器具間隔最大限 |         | 2.5           | 94  | 88  | 83  | 79   | 92  | 87  | 82  | 78   | 89  | 85 | 81 | 77   | 87 | 83 | 79 | 76  | 74 |
|        | 横方向 (A) | 縦方向 (B) | 3.0           | 96  | 91  | 87  | 83   | 95  | 90  | 86  | 82   | 92  | 88 | 84 | 81   | 89 | 86 | 83 | 80  | 78 |
| 1.5m   | 1.65 m  | 2.15 m  | 4.0           | 99  | 95  | 91  | 88   | 98  | 94  | 91  | 88   | 95  | 92 | 89 | 86   | 92 | 90 | 87 | 85  | 82 |
| 2      | 2.18    | 2.71    | 5.0           | 101 | 98  | 95  | 92   | 99  | 96  | 94  | 91   | 97  | 94 | 92 | 90   | 94 | 92 | 90 | 88  | 86 |
| 2.5    | 2.72    | 3.3     | 7.0           | 103 | 100 | 98  | 96   | 101 | 99  | 97  | 95   | 99  | 97 | 95 | 94   | 96 | 95 | 93 | 92  | 89 |
| 3      | 3.25    | 3.9     | 10.0          | 104 | 103 | 101 | 99   | 103 | 101 | 100 | 98   | 101 | 99 | 98 | 97   | 98 | 97 | 96 | 95  | 92 |

