

|          |                                                                  |  |
|----------|------------------------------------------------------------------|--|
| 屋内照明器具特性 |                                                                  |  |
| 品番 (品名)  | L G B 8 1 0 0 0                                                  |  |
| 光源       | L L D 2 0 0 0 C U 1    x 1                      5 6 6 . 0    l m |  |
| 管理番号     | K 0 1 7 8 9 1 3 ( 0 ) D R 1                                      |  |
| B Z 分類   | B Z 9 / 0 . 7 / B Z 8                                            |  |

| 器具効率   |                     | 92 %             | 反<br>射<br>率 | 天井                | 80 % |    |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |    |
|--------|---------------------|------------------|-------------|-------------------|------|----|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-----|----|
| 上方光束   |                     | 41 %             |             | 壁                 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |    |
| 下方光束   |                     | 51 %             |             | 床                 | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |    |
|        |                     |                  | 室指数         | 照明率 ( X0.01 ) ZCM |      |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     |    |
| 保守率    |                     |                  | 良           | 0.63              | 0.6  | 42 | 30 | 22 | 17   | 38 | 28 | 21 | 16   | 32 | 24 | 18 | 14   | 26 | 20 | 15 | 12  | 7  |
|        |                     |                  | 中           | 0.6               | 0.8  | 49 | 38 | 30 | 24   | 45 | 35 | 28 | 23   | 38 | 30 | 24 | 20   | 31 | 25 | 20 | 17  | 11 |
|        |                     |                  | 否           | 0.56              | 1.0  | 55 | 44 | 36 | 30   | 50 | 41 | 34 | 28   | 42 | 35 | 29 | 24   | 35 | 29 | 24 | 20  | 14 |
| 下方投影面積 |                     | c m <sup>2</sup> | 1.25        | 60                | 50   | 42 | 36 | 55 | 46   | 39 | 34 | 46 | 39   | 34 | 29 | 38 | 33   | 28 | 25 | 17 |     |    |
|        |                     |                  | 1.5         | 64                | 54   | 47 | 41 | 59 | 50   | 44 | 38 | 50 | 43   | 37 | 33 | 41 | 36   | 32 | 28 | 19 |     |    |
| 等価発光面積 |                     | c m <sup>2</sup> | 2.0         | 69                | 61   | 54 | 48 | 64 | 56   | 50 | 45 | 54 | 48   | 43 | 39 | 45 | 40   | 37 | 33 | 24 |     |    |
| 取付     | 器具間隔最大限             |                  | 2.5         | 72                | 65   | 59 | 53 | 67 | 60   | 55 | 50 | 57 | 52   | 47 | 43 | 48 | 44   | 40 | 37 | 27 |     |    |
| 高さ     | 横方向 ( A ) 縦方向 ( B ) |                  | 3.0         | 75                | 68   | 62 | 57 | 69 | 64   | 58 | 54 | 59 | 55   | 50 | 47 | 50 | 46   | 43 | 40 | 29 |     |    |
| H m    | 1.61 H m            | 1.66 H m         | 4.0         | 78                | 73   | 68 | 63 | 73 | 68   | 63 | 59 | 62 | 58   | 55 | 52 | 52 | 49   | 47 | 44 | 33 |     |    |
|        |                     |                  | 5.0         | 80                | 75   | 71 | 67 | 75 | 70   | 67 | 63 | 64 | 61   | 58 | 55 | 54 | 52   | 49 | 47 | 35 |     |    |
|        |                     |                  | 7.0         | 83                | 79   | 76 | 72 | 77 | 74   | 71 | 68 | 67 | 64   | 62 | 59 | 57 | 55   | 53 | 51 | 38 |     |    |
|        |                     |                  | 10.0        | 85                | 82   | 79 | 77 | 79 | 77   | 74 | 72 | 69 | 67   | 65 | 63 | 59 | 57   | 55 | 54 | 41 |     |    |

