

| 屋内照明器具特性 |                         |
|----------|-------------------------|
| 品番 (品名)  | XLGE1025                |
| 光源       | LLD2020VCE1 ×1 460.0 lm |
| 管理番号     | K0176348 (0) DR1        |
| BZ分類     | BZ1                     |

| 器具効率     |           | 91 %             | 反<br>射<br>率 | 天井            | 80 % |    |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |    |   |  |   |
|----------|-----------|------------------|-------------|---------------|------|----|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-----|----|---|--|---|
|          |           |                  |             | 壁             | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |    |   |  |   |
|          |           |                  |             | 床             | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |    |   |  |   |
| 上方光束     |           | 0 %              | 室指数         | 照明率 ( X0.01 ) |      |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     | Z  | C |  | M |
| 下方光束     |           | 91 %             |             |               |      |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     |    |   |  |   |
| 保守率      |           | 良<br>中<br>否      | 0.63        | 0.6           | 77   | 72 | 69 | 66 | 77   | 72 | 69 | 66 | 76   | 71 | 68 | 66 | 75   | 71 | 68 | 66 | 65  |    |   |  |   |
|          |           |                  | 0.6         | 0.8           | 83   | 78 | 75 | 72 | 82   | 78 | 75 | 72 | 81   | 77 | 74 | 72 | 79   | 76 | 74 | 72 | 71  |    |   |  |   |
|          |           |                  |             | 1.0           | 86   | 82 | 79 | 76 | 85   | 81 | 78 | 76 | 84   | 80 | 78 | 76 | 82   | 79 | 77 | 76 | 74  |    |   |  |   |
|          |           |                  | 0.56        | 1.25          | 89   | 85 | 82 | 80 | 88   | 84 | 82 | 80 | 86   | 83 | 81 | 79 | 85   | 82 | 80 | 79 | 77  |    |   |  |   |
| 下方投影面積   |           | c m <sup>2</sup> |             | 1.5           | 90   | 87 | 84 | 82 | 89   | 86 | 84 | 82 | 88   | 85 | 83 | 82 | 86   | 84 | 82 | 81 | 80  |    |   |  |   |
|          |           |                  |             | 2.0           | 92   | 90 | 88 | 86 | 92   | 89 | 87 | 85 | 90   | 88 | 86 | 85 | 88   | 87 | 85 | 84 | 82  |    |   |  |   |
| 取付<br>高さ | 器具間隔最大限   |                  |             | 2.5           | 94   | 92 | 90 | 88 | 93   | 91 | 89 | 88 | 91   | 89 | 88 | 87 | 89   | 88 | 87 | 86 | 84  |    |   |  |   |
|          | 横方向 ( A ) |                  | 縦方向 ( B )   |               | 3.0  | 95 | 93 | 91 | 90   | 94 | 92 | 90 | 89   | 92 | 90 | 89 | 88   | 90 | 89 | 88 | 87  | 85 |   |  |   |
| H m      | 0.41 H m  |                  | 0.41 H m    |               | 4.0  | 96 | 94 | 93 | 92   | 95 | 93 | 92 | 91   | 93 | 92 | 91 | 90   | 91 | 90 | 89 | 89  | 86 |   |  |   |
|          |           |                  |             |               | 5.0  | 96 | 95 | 94 | 93   | 95 | 94 | 93 | 92   | 93 | 92 | 92 | 91   | 92 | 91 | 90 | 90  | 87 |   |  |   |
|          |           |                  |             |               | 7.0  | 97 | 96 | 95 | 94   | 96 | 95 | 94 | 94   | 94 | 93 | 93 | 92   | 92 | 92 | 91 | 91  | 88 |   |  |   |
|          |           |                  |             | 10.0          | 98   | 97 | 96 | 96 | 97   | 96 | 95 | 95 | 95   | 94 | 94 | 93 | 93   | 92 | 92 | 92 | 92  | 89 |   |  |   |

