

# 屋内照明器具特性

|         |                             |  |  |  |  |  |  |  |  |  |
|---------|-----------------------------|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | LGBZ3427                    |  |  |  |  |  |  |  |  |  |
| 光源      | LED6200_70_5200 x1 5200.0lm |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0161808(0)D 1              |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ6/0.7/BZ5                 |  |  |  |  |  |  |  |  |  |

|        |                   |          |      |     |     |    |     |     |    |    |     |    |    |    |     |    |    |    |    |    |
|--------|-------------------|----------|------|-----|-----|----|-----|-----|----|----|-----|----|----|----|-----|----|----|----|----|----|
| 器具効率   | 100%              | 天井       | 80%  |     |     |    | 70% |     |    |    | 50% |    |    |    | 30% |    |    |    | 0% |    |
|        |                   | 壁        | 70   | 50  | 30  | 10 | 70  | 50  | 30 | 10 | 70  | 50 | 30 | 10 | 70  | 50 | 30 | 10 | 0% |    |
|        |                   | 床        | 10%  |     |     |    | 10% |     |    |    | 10% |    |    |    | 10% |    |    |    | 0% |    |
| 上方光束   | 3%                |          |      |     |     |    |     |     |    |    |     |    |    |    |     |    |    |    |    |    |
| 下方光束   | 97%               |          |      |     |     |    |     |     |    |    |     |    |    |    |     |    |    |    |    |    |
| 室指数    | 照明率 ( X0.01 ) ZCM |          |      |     |     |    |     |     |    |    |     |    |    |    |     |    |    |    |    |    |
| 保守率    | 良                 | 0.63     | 0.6  | 53  | 41  | 32 | 27  | 52  | 40 | 32 | 26  | 49 | 38 | 31 | 26  | 47 | 37 | 31 | 26 | 24 |
|        | 中                 | 0.6      | 0.8  | 63  | 51  | 43 | 37  | 62  | 50 | 42 | 36  | 59 | 49 | 41 | 36  | 56 | 47 | 41 | 36 | 33 |
|        | 否                 | 0.56     | 1.0  | 70  | 59  | 50 | 44  | 68  | 58 | 50 | 44  | 65 | 56 | 49 | 43  | 62 | 54 | 48 | 43 | 40 |
|        |                   |          | 1.25 | 76  | 66  | 58 | 52  | 74  | 65 | 57 | 51  | 71 | 62 | 56 | 50  | 67 | 60 | 54 | 50 | 47 |
| 下方投影面積 | c m <sup>2</sup>  |          | 1.5  | 81  | 71  | 63 | 57  | 79  | 70 | 63 | 57  | 75 | 67 | 61 | 56  | 71 | 65 | 60 | 55 | 52 |
| 等価発光面積 | c m <sup>2</sup>  |          | 2.0  | 86  | 78  | 71 | 66  | 84  | 77 | 71 | 65  | 81 | 74 | 69 | 64  | 77 | 72 | 67 | 63 | 60 |
| 取付高さ   | 器具間隔最大限           |          | 2.5  | 90  | 83  | 77 | 72  | 88  | 82 | 76 | 71  | 84 | 79 | 74 | 70  | 81 | 76 | 72 | 69 | 65 |
|        | 横方向 (A)           | 縦方向 (B)  | 3.0  | 93  | 86  | 81 | 76  | 91  | 85 | 80 | 76  | 87 | 82 | 78 | 74  | 84 | 80 | 76 | 73 | 69 |
| H m    | 1.46 H m          | 1.46 H m | 4.0  | 96  | 91  | 87 | 82  | 94  | 90 | 85 | 82  | 91 | 87 | 83 | 80  | 87 | 84 | 81 | 78 | 75 |
|        |                   |          | 5.0  | 98  | 94  | 90 | 87  | 96  | 92 | 89 | 86  | 93 | 90 | 87 | 84  | 90 | 87 | 84 | 82 | 78 |
|        |                   |          | 7.0  | 101 | 97  | 94 | 92  | 99  | 96 | 93 | 91  | 96 | 93 | 91 | 88  | 92 | 90 | 88 | 86 | 83 |
|        |                   |          | 10.0 | 103 | 100 | 98 | 96  | 101 | 99 | 97 | 95  | 98 | 96 | 94 | 92  | 95 | 93 | 92 | 90 | 86 |

