

屋内照明器具特性	
品番 (品名)	S L B 8 1 3 0 7
光源	L L D 2 4 1 1 L C B 1 × 1 5 0 0 . 0 l m
管理番号	K 0 1 9 4 7 8 7 (0) D R 1
B Z 分類	B Z 1

器具効率		9 9 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %		
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %		
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %		
上方光束		4 9 %	室指数	照明率 (X 0 . 0 1)																			Z C M
下方光束		5 0 %																					
保守率		良 中 否	0 . 6 7	0 . 6	6 7	5 9	5 5	5 1	6 3	5 7	5 3	5 0	5 7	5 2	4 9	4 7	5 1	4 8	4 6	4 4	4 0		
			0 . 6 3	0 . 8	7 3	6 6	6 1	5 8	6 9	6 3	5 9	5 6	6 1	5 7	5 4	5 2	5 4	5 2	5 0	4 8	4 2		
			0 . 5 6	1 . 0	7 7	7 0	6 6	6 2	7 2	6 7	6 3	6 0	6 4	6 0	5 7	5 5	5 6	5 4	5 2	5 1	4 4		
				1 . 2 5	8 0	7 4	7 0	6 7	7 5	7 1	6 7	6 4	6 6	6 3	6 0	5 8	5 8	5 6	5 4	5 3	4 5		
下方投影面積		c m ²	1 . 5	8 3	7 7	7 3	7 0	7 8	7 3	7 0	6 7	6 8	6 5	6 3	6 1	5 9	5 7	5 6	5 5	4 5			
等価発光面積		c m ²	2 . 0	8 6	8 2	7 8	7 5	8 1	7 7	7 4	7 1	7 0	6 8	6 6	6 4	6 1	5 9	5 8	5 7	4 6			
取付 高さ	器具間隔最大限		2 . 5	8 8	8 4	8 1	7 9	8 2	7 9	7 7	7 4	7 2	7 0	6 8	6 6	6 2	6 1	6 0	5 9	4 7			
	横方向 (A)		縦方向 (B)	3 . 0	8 9	8 6	8 3	8 1	8 4	8 1	7 9	7 7	7 3	7 1	6 9	6 8	6 3	6 1	6 1	6 0	4 7		
H m	0 . 7 8 H m	0 . 7 8 H m	4 . 0	9 1	8 9	8 6	8 4	8 5	8 3	8 1	8 0	7 4	7 3	7 1	7 0	6 3	6 3	6 2	6 1	4 8			
			5 . 0	9 2	9 0	8 8	8 7	8 6	8 5	8 3	8 1	7 5	7 4	7 3	7 2	6 4	6 3	6 3	6 2	4 8			
			7 . 0	9 4	9 2	9 1	8 9	8 7	8 6	8 5	8 4	7 6	7 5	7 4	7 3	6 5	6 4	6 4	6 3	4 9			
			1 0 . 0	9 5	9 3	9 2	9 1	8 8	8 7	8 7	8 6	7 6	7 6	7 5	7 5	6 5	6 5	6 4	6 4	4 9			

