

-
- 端子台側向



- 電源線
- 間違った端子台向き
- 正しい端子台向き
- 端子台（電源線投入部）
-
- The diagram illustrates the correct and incorrect ways to connect a power line to a terminal block. The top part shows an incorrect connection where the power line is inserted into the terminal block from the side, marked with a large 'X'. The bottom part shows the correct connection where the power line is inserted into the terminal block from the front, marked with a circle containing a plus sign. Labels indicate '電源線' (Power line), '間違った端子台向き' (Incorrect terminal block orientation), '正しい端子台向き' (Correct terminal block orientation), and '端子台（電源線投入部）' (Terminal block (power line input part)).

- | | | | | |
|-----|----|-------|-------|-------|
| | 電圧 | 100V | 200V | 242V |
| LZ9 | 電流 | 0.11A | 0.06A | 0.05A |
| LE9 | 電力 | 11W | 11W | 11W |

C