

屋内照明器具特性	
品番 (品名)	NND2 6 0 4 1 K
光源	LEDALL_90_80.8 ×1 80.8 l m
管理番号	K0146009 (0) DD 1
BZ分類	BZ3 / 2.8 / BZ4

器具効率		1 0 0 % 上方光束 4 % 下方光束 9 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
			室指数	照明率 (X 0 . 0 1) Z C M																	
保守率		良 中 否	0 . 8 8	0 . 6	6 3	5 2	4 5	4 0	6 1	5 1	4 5	4 0	5 9	5 0	4 4	4 0	5 7	4 9	4 4	4 0	3 8
			0 . 8 6	0 . 8	7 2	6 2	5 5	5 0	7 0	6 1	5 5	5 0	6 8	6 0	5 4	5 0	6 5	5 8	5 3	4 9	4 7
			0 . 8 1	1 . 0	7 8	6 9	6 2	5 8	7 6	6 8	6 2	5 7	7 3	6 6	6 1	5 7	7 1	6 5	6 0	5 6	5 4
下方投影面積 等価発光面積		c m ² c m ²	1 . 2 5	8 3	7 5	6 9	6 4	8 2	7 4	6 8	6 4	7 9	7 2	6 7	6 3	7 6	7 0	6 6	6 2	6 0	
			1 . 5	8 7	7 9	7 4	6 9	8 5	7 8	7 3	6 9	8 2	7 6	7 2	6 8	7 9	7 4	7 0	6 7	6 4	
			2 . 0	9 2	8 5	8 0	7 6	9 0	8 4	8 0	7 6	8 7	8 2	7 8	7 4	8 4	8 0	7 6	7 3	7 0	
取付 高さ	器具間隔最大限		2 . 5	9 4	8 9	8 5	8 1	9 3	8 8	8 4	8 0	8 9	8 5	8 2	7 9	8 6	8 3	8 0	7 7	7 4	
	横方向 (A) 縦方向 (B)		3 . 0	9 6	9 2	8 8	8 4	9 5	9 1	8 7	8 4	9 2	8 8	8 5	8 2	8 8	8 6	8 3	8 1	7 7	
H m	0 . 8 3 H m	1 . 2 5 H m	4 . 0	9 9	9 5	9 2	8 9	9 7	9 4	9 1	8 8	9 4	9 1	8 9	8 6	9 1	8 9	8 7	8 5	8 1	
			5 . 0	1 0 1	9 8	9 5	9 2	9 9	9 6	9 4	9 1	9 6	9 3	9 1	8 9	9 3	9 1	8 9	8 7	8 4	
			7 . 0	1 0 2	1 0 0	9 8	9 6	1 0 1	9 9	9 7	9 5	9 8	9 6	9 4	9 3	9 5	9 3	9 2	9 0	8 7	
			1 0 . 0	1 0 4	1 0 2	1 0 0	9 9	1 0 2	1 0 1	9 9	9 8	9 9	9 8	9 6	9 5	9 6	9 5	9 4	9 3	8 9	

