

屋内照明器具特性	
品番 (品名)	L G B 8 1 0 0 1
光源	L L D 4 0 0 0 L C B 1 × 1 8 4 5 . 0 l m
管理番号	K 0 1 7 6 4 1 0 (0) D R 1
B Z 分類	B Z 4

器具効率		4 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %	
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %	
					床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
						照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 3	0 . 6	2 2	1 7	1 5	1 3	2 1	1 7	1 4	1 2	1 9	1 5	1 3	1 2	1 7	1 4	1 2	1 1	9	
			0 . 6	0 . 8	2 6	2 2	1 9	1 7	2 4	2 1	1 8	1 6	2 2	1 9	1 7	1 5	2 0	1 7	1 6	1 4	1 2	
			0 . 5 6	1 . 0	2 8	2 4	2 2	2 0	2 7	2 3	2 1	1 9	2 4	2 1	1 9	1 8	2 2	2 0	1 8	1 7	1 4	
				1 . 2 5	3 1	2 7	2 4	2 2	2 9	2 6	2 4	2 2	2 6	2 4	2 2	2 0	2 4	2 2	2 0	1 9	1 6	
下方投影面積		c m ²	1 . 5	3 2	2 9	2 7	2 5	3 1	2 8	2 6	2 4	2 8	2 5	2 4	2 2	2 5	2 3	2 2	2 1	1 8		
			等価発光面積	2 . 0	3 4	3 2	2 9	2 8	3 2	3 0	2 8	2 7	2 9	2 8	2 6	2 5	2 7	2 5	2 4	2 3	2 0	
取付高さ	器具間隔最大限		2 . 5	3 5	3 3	3 1	3 0	3 4	3 2	3 0	2 9	3 1	2 9	2 8	2 7	2 8	2 6	2 5	2 5	2 1		
	横方向 (A)	縦方向 (B)	3 . 0	3 6	3 4	3 3	3 1	3 5	3 3	3 1	3 0	3 1	3 0	2 9	2 8	2 8	2 7	2 6	2 6	2 2		
H m	1 . 1 5 H m	1 . 2 6 H m	4 . 0	3 7	3 6	3 5	3 3	3 6	3 4	3 3	3 2	3 2	3 1	3 0	3 0	2 9	2 9	2 8	2 7	2 3		
			5 . 0	3 8	3 7	3 6	3 5	3 6	3 5	3 4	3 3	3 3	3 2	3 1	3 1	3 0	2 9	2 9	2 8	2 4		
			7 . 0	3 9	3 8	3 7	3 6	3 7	3 6	3 5	3 5	3 4	3 3	3 3	3 2	3 1	3 0	3 0	2 9	2 5		
			1 0 . 0	3 9	3 9	3 8	3 7	3 8	3 7	3 6	3 6	3 4	3 4	3 3	3 3	3 1	3 1	3 0	3 0	2 6		

