

屋内照明器具特性	
品番 (品名)	L G B 8 1 0 0 8
光源	L L D 4 0 0 0 L C B 1 × 1 8 4 5 . 0 l m
管理番号	K 0 1 7 6 4 1 6 (0) D R 1
B Z 分類	B Z 5 / 0 . 7 / B Z 4

器具効率		3 8 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 3	0 . 6	1 9	1 5	1 2	1 0	1 8	1 4	1 2	1 0	1 5	1 2	1 0	9	1 3	1 0	9	8	6
			0 . 6	0 . 8	2 3	1 9	1 6	1 4	2 1	1 8	1 5	1 3	1 8	1 5	1 3	1 2	1 5	1 3	1 2	1 0	8
			0 . 5 6	1 . 0	2 5	2 2	1 9	1 7	2 3	2 0	1 8	1 6	2 0	1 7	1 6	1 4	1 7	1 5	1 4	1 2	9
				1 . 2 5	2 7	2 4	2 2	2 0	2 5	2 3	2 0	1 9	2 2	1 9	1 8	1 6	1 8	1 7	1 5	1 4	1 1
下方投影面積		c m ²	1 . 5	2 9	2 6	2 4	2 2	2 7	2 4	2 2	2 0	2 3	2 1	1 9	1 8	1 9	1 8	1 7	1 6	1 2	
			等価発光面積	c m ²	2 . 0	3 1	2 8	2 6	2 5	2 9	2 6	2 5	2 3	2 4	2 3	2 2	2 0	2 1	1 9	1 8	1 8
取付 高さ	器具間隔最大限		2 . 5	3 2	3 0	2 8	2 7	3 0	2 8	2 6	2 5	2 5	2 4	2 3	2 2	2 1	2 1	2 0	1 9	1 4	
	横方向 (A) 縦方向 (B)		3 . 0	3 3	3 1	2 9	2 8	3 1	2 9	2 8	2 6	2 6	2 5	2 4	2 3	2 2	2 1	2 1	2 0	1 5	
H m	0 . 0 0 H m	1 . 6 4 H m	4 . 0	3 4	3 3	3 1	3 0	3 2	3 0	2 9	2 8	2 7	2 6	2 5	2 5	2 3	2 2	2 2	2 1	1 6	
			5 . 0	3 5	3 3	3 2	3 1	3 2	3 1	3 0	2 9	2 8	2 7	2 6	2 6	2 3	2 3	2 2	2 2	1 6	
			7 . 0	3 5	3 4	3 4	3 3	3 3	3 2	3 1	3 1	2 8	2 8	2 7	2 7	2 4	2 4	2 3	2 3	1 7	
			1 0 . 0	3 6	3 5	3 5	3 4	3 3	3 3	3 2	3 2	2 9	2 8	2 8	2 8	2 4	2 4	2 4	2 4	1 8	

