

# 屋内照明器具特性

品番 (品名)	LRD9 1 0 2	
光源	LLD3 0 2 0 MLCB1 ×1	7 1 5 . 0 1 m
管理番号	K0 1 7 5 9 7 8 ( 0 ) DR 1	
B Z 分類	B Z 1	

器具効率	5 6 %	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %							
	上方光束 0 %		壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %						
下方光束	5 6 %	床		1 0 %				1 0 %				1 0 %				1 0 %				0 %						
室指数	照明率 ( X 0 . 0 1 )																			Z C M						
保守率	良	0 . 6 3	0 . 6	0 . 5 6	0 . 6	4 6	4 2	4 0	3 9	4 6	4 2	4 0	3 8	4 5	4 2	4 0	3 8	4 4	4 1	4 0	3 8	3 8				
	中	0 . 6	0 . 6	0 . 6	0 . 8	4 9	4 6	4 4	4 2	4 9	4 6	4 4	4 2	4 8	4 6	4 4	4 2	4 7	4 5	4 3	4 2	4 1				
	否	0 . 5 6	0 . 5 6	0 . 5 6	1 . 0	5 2	4 9	4 7	4 5	5 1	4 8	4 6	4 5	5 0	4 8	4 6	4 5	4 9	4 7	4 6	4 5	4 4				
下方投影面積 等価発光面積	c m <sup>2</sup>	1 . 2 5	1 . 5	2 . 0	2 . 5	5 3	5 1	4 9	4 8	5 3	5 1	4 9	4 7	5 2	5 0	4 8	4 7	5 1	4 9	4 8	4 7	4 6				
		2 . 0	2 . 5	5 6	5 4	5 3	5 2	5 5	5 4	5 2	5 1	5 4	5 3	5 2	5 1	5 3	5 2	5 1	5 3	5 2	5 1	5 0	4 9			
取付高さ	器具間隔最大限		H m	0 . 4 1 H m	H m	0 . 4 1 H m	3 . 0	4 . 0	5 . 0	7 . 0	1 0 . 0	5 7	5 5	5 4	5 3	5 6	5 5	5 4	5 3	5 5	5 4	5 3	5 2	5 1		
	横方向 ( A )	縦方向 ( B )					3 . 0	4 . 0	5 . 0	7 . 0	1 0 . 0	5 8	5 6	5 5	5 4	5 7	5 6	5 5	5 4	5 6	5 5	5 4	5 3	5 5	5 4	5 3
						4 . 0	5 . 0	7 . 0	1 0 . 0	5 8	5 7	5 6	5 5	5 8	5 7	5 6	5 5	5 6	5 5	5 4	5 5	5 5	5 4	5 4	5 2	
						5 . 0	7 . 0	1 0 . 0	5 9	5 8	5 7	5 6	5 8	5 7	5 7	5 6	5 7	5 6	5 5	5 6	5 5	5 6	5 5	5 5	5 4	5 3
						7 . 0	1 0 . 0	5 9	5 9	5 8	5 7	5 9	5 8	5 7	5 7	5 7	5 7	5 6	5 6	5 6	5 6	5 6	5 5	5 5	5 4	5 4
						1 0 . 0	6 0	5 9	5 9	5 8	5 9	5 8	5 8	5 8	5 8	5 8	5 8	5 7	5 7	5 7	5 6	5 6	5 6	5 6	5 6	5 4

