

| 屋内照明器具特性 |                         |
|----------|-------------------------|
| 品番 (品名)  | XLGB1014                |
| 光源       | LLD2000LCE1 ×1 531.0 lm |
| 管理番号     | K0176328 ( 0 ) DR 1     |
| BZ分類     | BZ4                     |

| 器具効率     |                     | 87 %            | 反射率  | 天井   | 80 %          |    |    |    | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |
|----------|---------------------|-----------------|------|------|---------------|----|----|----|------|----|----|----|------|----|----|----|------|----|----|----|-----|
|          |                     |                 |      | 壁    | 70            | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |
|          |                     |                 |      | 床    | 10 %          |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |
|          |                     |                 |      | 室指数  | 照明率 ( X0.01 ) |    |    |    |      |    |    |    |      |    |    |    |      |    |    |    |     |
| 保守率      |                     | 良<br>中<br>否     | 0.67 | 0.6  | 50            | 40 | 34 | 29 | 49   | 39 | 33 | 29 | 46   | 38 | 33 | 29 | 44   | 37 | 32 | 28 | 26  |
|          |                     |                 | 0.63 | 0.8  | 59            | 50 | 44 | 39 | 58   | 49 | 43 | 39 | 55   | 47 | 42 | 38 | 52   | 46 | 41 | 37 | 35  |
|          |                     |                 | 0.56 | 1.0  | 65            | 57 | 51 | 46 | 64   | 56 | 50 | 46 | 60   | 54 | 49 | 45 | 58   | 52 | 48 | 44 | 42  |
|          |                     |                 |      | 1.25 | 70            | 63 | 57 | 53 | 69   | 62 | 56 | 52 | 65   | 60 | 55 | 51 | 62   | 58 | 54 | 50 | 48  |
| 下方投影面積   |                     | cm <sup>2</sup> |      | 1.5  | 74            | 67 | 62 | 58 | 72   | 66 | 61 | 57 | 69   | 64 | 59 | 56 | 66   | 61 | 58 | 55 | 52  |
|          |                     |                 |      | 2.0  | 78            | 73 | 68 | 65 | 77   | 71 | 67 | 64 | 73   | 69 | 65 | 62 | 70   | 67 | 64 | 61 | 58  |
| 取付<br>高さ | 器具間隔最大限             |                 |      | 2.5  | 81            | 76 | 72 | 69 | 79   | 75 | 71 | 68 | 76   | 72 | 69 | 67 | 73   | 70 | 67 | 65 | 62  |
|          | 横方向 ( A ) 縦方向 ( B ) |                 |      | 3.0  | 83            | 79 | 75 | 72 | 81   | 77 | 74 | 71 | 78   | 75 | 72 | 70 | 75   | 72 | 70 | 68 | 65  |
| H m      | 1.32 H m 1.32 H m   |                 |      | 4.0  | 85            | 82 | 79 | 77 | 84   | 81 | 78 | 76 | 80   | 78 | 76 | 74 | 77   | 75 | 73 | 72 | 68  |
|          |                     |                 |      | 5.0  | 87            | 84 | 82 | 79 | 85   | 83 | 80 | 78 | 82   | 80 | 78 | 76 | 79   | 77 | 75 | 74 | 70  |
|          |                     |                 |      | 7.0  | 88            | 86 | 84 | 83 | 87   | 85 | 83 | 81 | 83   | 82 | 80 | 79 | 80   | 79 | 78 | 77 | 73  |
|          |                     |                 |      | 10.0 | 90            | 88 | 87 | 85 | 88   | 87 | 85 | 84 | 85   | 84 | 82 | 81 | 82   | 81 | 80 | 79 | 75  |

