

屋内照明器具特性

| | | | | | |
|---------|----------------------------------------------|--|--|--|--|
| 品番 (品名) | LGB16736 | | | | |
| 光源 | LLD4000LCE1 ×1 845.0 lm | | | | |
| 管理番号 | K0176189(0)DR1 | | | | |
| BZ分類 | BZ5 | | | | |

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-------------|------------|----------------------------------------|------------------|------|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|--|-----|--|-----|--|-----|--|-----|--|-----|--|-----|--|-----|--|-----|--|
| 器具効率 | 71% | 天井 | 80% | | | | 70% | | | | 50% | | | | 30% | | | | 0% | | | | | | | | | | | | | | | | | | | | | |
| | 上方光束 4% | | 反射率 | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0% | | | | | | | | | | | | | | | | | | | |
| | | | | 床 | 10% | | | | 10% | | | | 10% | | | | 10% | | | | 0% | | | | | | | | | | | | | | | | | | | |
| 下方光束 67% | 室指数 | 照明率 (X0.01) ZCM | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 | 0.67 | 0.6 | 3.9 | 3.0 | 2.5 | 2.1 | 3.8 | 3.0 | 2.4 | 2.1 | 3.6 | 2.9 | 2.4 | 2.0 | 3.4 | 2.8 | 2.3 | 2.0 | 1.8 | | | | | | | | | | | | | | | | | | | | |
| | 中 | 0.63 | 0.8 | 4.6 | 3.8 | 3.2 | 2.8 | 4.5 | 3.7 | 3.1 | 2.8 | 4.2 | 3.6 | 3.1 | 2.7 | 4.0 | 3.4 | 3.0 | 2.7 | 2.5 | | | | | | | | | | | | | | | | | | | | |
| | 否 | 0.56 | 1.0 | 5.1 | 4.3 | 3.7 | 3.3 | 4.9 | 4.2 | 3.7 | 3.3 | 4.7 | 4.0 | 3.6 | 3.2 | 4.4 | 3.9 | 3.5 | 3.1 | 2.9 | | | | | | | | | | | | | | | | | | | | |
| | | | 0.56 | 1.25 | 5.5 | 4.8 | 4.2 | 3.8 | 5.3 | 4.7 | 4.2 | 3.8 | 5.1 | 4.5 | 4.1 | 3.7 | 4.8 | 4.3 | 3.9 | 3.6 | 3.4 | | | | | | | | | | | | | | | | | | | |
| 下方投影面積 | | | c m ² | | 1.5 | | 5.8 | | 5.1 | | 4.6 | | 4.2 | | 5.6 | | 5.0 | | 4.5 | | 4.2 | | 5.3 | | 4.8 | | 4.4 | | 4.1 | | 5.1 | | 4.7 | | 4.3 | | 4.0 | | 3.8 | |
| | 等価発光面積 | | c m ² | | 2.0 | | 6.2 | | 5.6 | | 5.2 | | 4.8 | | 6.0 | | 5.5 | | 5.1 | | 4.8 | | 5.7 | | 5.3 | | 5.0 | | 4.6 | | 5.5 | | 5.1 | | 4.8 | | 4.5 | | 4.3 | |
| 取付高さ | 器具間隔最大限 | | | | 2.5 | | 6.4 | | 6.0 | | 5.6 | | 5.2 | | 6.3 | | 5.9 | | 5.5 | | 5.2 | | 6.0 | | 5.6 | | 5.3 | | 5.0 | | 5.7 | | 5.4 | | 5.2 | | 4.9 | | 4.7 | |
| | 横方向 (A) | | 縦方向 (B) | | 3.0 | | 6.6 | | 6.2 | | 5.8 | | 5.5 | | 6.5 | | 6.1 | | 5.8 | | 5.5 | | 6.2 | | 5.9 | | 5.6 | | 5.3 | | 5.9 | | 5.7 | | 5.4 | | 5.2 | | 4.9 | |
| H m | 1.17 H m | 1.17 H m | | | 4.0 | | 6.8 | | 6.5 | | 6.2 | | 6.0 | | 6.7 | | 6.4 | | 6.1 | | 5.9 | | 6.4 | | 6.2 | | 5.9 | | 5.7 | | 6.2 | | 6.0 | | 5.8 | | 5.6 | | 5.3 | |
| | | | | | 5.0 | | 7.0 | | 6.7 | | 6.5 | | 6.2 | | 6.8 | | 6.6 | | 6.4 | | 6.2 | | 6.6 | | 6.4 | | 6.2 | | 6.0 | | 6.3 | | 6.1 | | 6.0 | | 5.8 | | 5.5 | |
| | | | | | 7.0 | | 7.2 | | 6.9 | | 6.8 | | 6.6 | | 7.0 | | 6.8 | | 6.6 | | 6.5 | | 6.8 | | 6.6 | | 6.4 | | 6.3 | | 6.5 | | 6.4 | | 6.2 | | 6.1 | | 5.8 | |
| | | | | | 10.0 | | 7.3 | | 7.1 | | 7.0 | | 6.9 | | 7.1 | | 7.0 | | 6.9 | | 6.7 | | 6.9 | | 6.8 | | 6.7 | | 6.6 | | 6.6 | | 6.5 | | 6.5 | | 6.4 | | 6.1 | |

