

屋内照明器具特性	
品番 (品名)	L G S 9 5 0 6
光源	L L D 2 0 0 0 M L C E 1 × 1 5 3 1 . 0 l m
管理番号	K 0 1 9 1 3 7 7 (1) D R 1
B Z 分類	B Z 1

器具効率		3 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 7	0 . 6	2 8	2 5	2 4	2 2	2 7	2 5	2 3	2 2	2 7	2 5	2 3	2 2	2 6	2 5	2 3	2 2	2 2
			0 . 6 3	0 . 8	3 1	2 8	2 7	2 6	3 0	2 8	2 7	2 6	3 0	2 8	2 6	2 5	2 9	2 7	2 6	2 5	2 5
			0 . 5 6	1 . 0	3 2	3 0	2 9	2 8	3 2	3 0	2 9	2 8	3 1	3 0	2 8	2 8	3 1	2 9	2 8	2 7	2 7
				1 . 2 5	3 4	3 2	3 1	3 0	3 3	3 2	3 0	2 9	3 3	3 1	3 0	2 9	3 2	3 1	3 0	2 9	2 9
下方投影面積		c m ²	1 . 5	3 4	3 3	3 2	3 1	3 4	3 3	3 2	3 1	3 3	3 2	3 1	3 0	3 3	3 2	3 1	3 0	3 0	
			等価発光面積	c m ²	2 . 0	3 5	3 4	3 3	3 2	3 5	3 4	3 3	3 2	3 4	3 3	3 3	3 2	3 4	3 3	3 2	3 2
取付 高さ	器具間隔最大限		2 . 5	3 6	3 5	3 4	3 3	3 6	3 5	3 4	3 3	3 5	3 4	3 4	3 3	3 4	3 4	3 3	3 3	3 2	
	横方向 (A) 縦方向 (B)		3 . 0	3 7	3 6	3 5	3 4	3 6	3 5	3 5	3 4	3 5	3 5	3 4	3 4	3 5	3 4	3 4	3 3	3 2	
H m	1 . 0 2 H m	1 . 0 2 H m	4 . 0	3 7	3 6	3 6	3 5	3 7	3 6	3 5	3 5	3 6	3 5	3 5	3 4	3 5	3 5	3 4	3 4	3 3	
			5 . 0	3 7	3 7	3 6	3 6	3 7	3 6	3 6	3 6	3 6	3 6	3 5	3 5	3 5	3 5	3 5	3 4	3 4	
			7 . 0	3 8	3 7	3 7	3 7	3 7	3 7	3 7	3 6	3 6	3 6	3 6	3 6	3 6	3 5	3 5	3 5	3 4	
			1 0 . 0	3 8	3 8	3 7	3 7	3 8	3 7	3 7	3 7	3 7	3 7	3 6	3 6	3 6	3 6	3 6	3 5	3 5	

