

屋内照明器具特性	
品番 (品名)	L G W C 8 5 2 1 9 F
光源	L D A 4 L - H - E 1 7 / S / 4 × 1 4 4 0 . 0 l m
管理番号	K 0 1 8 9 6 7 3 (0) D B 1
B Z 分類	B Z 7

器具効率		48 %	反射率	天井	80 %				70 %				50 %				30 %				0 %		
				壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %		
				床	10 %				10 %				10 %				10 %				0 %		
上方光束		8 %	室指数	照明率 (X0.01)																			Z C M
下方光束		40 %																					
保守率		良	0.63	0.6	23	17	13	10	22	16	12	10	20	15	12	9	18	14	11	9	7		
		中	0.6	0.8	28	21	17	14	26	20	16	13	24	19	15	13	21	17	14	12	10		
		否	0.56	1.0	31	24	20	17	29	24	19	16	26	22	18	15	24	20	17	15	12		
				1.25	33	28	23	20	32	27	23	19	29	24	21	18	26	23	20	17	15		
下方投影面積		c m ²		1.5	35	30	26	23	34	29	25	22	31	27	23	21	28	25	22	19	17		
等価発光面積		c m ²		2.0	38	34	30	27	37	32	29	26	33	30	27	24	30	27	25	23	20		
取付高さ	器具間隔最大限			2.5	40	36	32	29	38	35	31	29	35	32	29	27	32	30	27	25	22		
	横方向 (A)		縦方向 (B)	3.0	41	38	35	32	40	36	33	31	36	34	31	29	33	31	29	27	24		
H m	1.46 H m	1.45 H m	4.0	43	40	37	35	42	39	36	34	38	36	34	32	35	33	32	30	27			
			5.0	44	42	39	37	43	40	38	36	39	37	36	34	36	35	33	32	28			
			7.0	46	44	42	40	44	42	40	39	41	39	38	36	38	37	35	34	31			
			10.0	47	45	44	42	45	44	42	41	42	41	40	39	39	38	37	36	33			

