

# 屋内照明器具特性

品番 (品名)	XAD3 200 V	
光源	LLD4000VCS1 ×1	830.0 lm
管理番号	K0181859 (0) DR 1	
BZ分類	BZ4 / 0.9 / BZ3	

器具効率	83 %	天井	80 %				70 %				50 %				30 %				0 %	
		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %	
上方光束	0 %	床	10 %				10 %				10 %				10 %				0 %	
下方光束	83 %	室指数	照明率 ( X0.01 )																ZCM	
保守率	良 中 否 0.67 0.63 0.56	0.6	51	41	35	31	50	41	35	31	48	40	35	31	46	39	34	31	29	
		0.8	59	50	45	40	58	50	44	40	56	49	44	40	54	48	43	40	38	
		1.0	65	57	51	47	63	56	51	47	61	55	50	46	59	54	50	46	45	
		1.25	69	62	57	53	68	62	57	53	66	60	56	53	64	59	55	52	50	
下方投影面積	c m <sup>2</sup>	1.5	73	66	62	58	71	66	61	57	69	64	60	57	67	63	59	56	55	
		2.0	77	72	68	64	76	71	67	64	73	69	66	63	71	68	65	62	61	
取付高さ	器具間隔最大限		2.5	80	75	72	68	78	74	71	68	76	73	70	67	74	71	69	66	65
	横方向 (A)	縦方向 (B)	3.0	81	78	74	72	80	77	74	71	78	75	72	70	76	73	71	69	67
H m	1.26 H m	1.26 H m	4.0	83	81	78	76	82	80	77	75	80	78	76	74	78	76	75	73	71
			5.0	85	82	80	78	84	81	79	78	82	80	78	76	80	78	77	75	73
			7.0	86	85	83	81	85	84	82	81	83	82	81	79	81	80	79	78	76
			10.0	87	86	85	84	86	85	84	83	84	83	82	82	82	82	81	80	78

