

# 屋内照明器具特性

|         |                              |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|---------|------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | LGC31620                     |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 光源      | LED6200_70_4299 x1 4299.0 lm |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0178552(0)D 1               |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ5                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

|        |         |         |      |                   |      |     |     |      |     |     |     |     |     |     |     |     |     |     |     |     |
|--------|---------|---------|------|-------------------|------|-----|-----|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 器具効率   | 100%    | 天井      | 80%  |                   |      |     | 70% |      |     |     | 50% |     |     |     | 30% |     |     |     | 0%  |     |
|        |         |         | 壁    | 70                | 50   | 30  | 10  | 70   | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 0%  |
| 上方光束   | 7%      | 反射率     | 床    | 10%               |      |     |     | 10%  |     |     |     | 10% |     |     |     | 10% |     |     |     | 0%  |
| 下方光束   | 93%     |         | 室指数  | 照明率 ( X0.01 ) ZCM |      |     |     |      |     |     |     |     |     |     |     |     |     |     |     |     |
| 保守率    | 良       | 0.63    | 0.6  | 5.5               | 4.3  | 3.5 | 3.0 | 5.3  | 4.2 | 3.5 | 2.9 | 5.0 | 4.0 | 3.4 | 2.9 | 4.8 | 3.9 | 3.3 | 2.8 | 2.6 |
|        | 中       | 0.6     | 0.8  | 6.5               | 5.3  | 4.6 | 4.0 | 6.3  | 5.2 | 4.5 | 3.9 | 6.0 | 5.0 | 4.4 | 3.9 | 5.6 | 4.8 | 4.3 | 3.8 | 3.5 |
|        | 否       | 0.56    | 1.0  | 7.2               | 6.1  | 5.3 | 4.7 | 7.0  | 6.0 | 5.2 | 4.7 | 6.6 | 5.7 | 5.1 | 4.6 | 6.2 | 5.5 | 4.9 | 4.5 | 4.2 |
|        |         |         | 1.25 | 7.8               | 6.8  | 6.0 | 5.5 | 7.6  | 6.6 | 6.0 | 5.4 | 7.1 | 6.4 | 5.8 | 5.3 | 6.8 | 6.1 | 5.6 | 5.2 | 4.9 |
| 下方投影面積 |         |         | 1.5  | 8.2               | 7.3  | 6.6 | 6.0 | 8.0  | 7.1 | 6.5 | 6.0 | 7.5 | 6.9 | 6.3 | 5.8 | 7.2 | 6.6 | 6.1 | 5.7 | 5.4 |
| 等価発光面積 |         |         | 2.0  | 8.7               | 8.0  | 7.4 | 6.9 | 8.5  | 7.8 | 7.3 | 6.8 | 8.1 | 7.5 | 7.0 | 6.6 | 7.7 | 7.2 | 6.8 | 6.5 | 6.1 |
| 取付高さ   | 器具間隔最大限 |         | 2.5  | 9.1               | 8.5  | 7.9 | 7.4 | 8.9  | 8.3 | 7.8 | 7.3 | 8.5 | 8.0 | 7.5 | 7.2 | 8.1 | 7.7 | 7.3 | 7.0 | 6.6 |
|        | 横方向 (A) | 縦方向 (B) | 3.0  | 9.3               | 8.8  | 8.3 | 7.9 | 9.1  | 8.6 | 8.2 | 7.8 | 8.7 | 8.3 | 7.9 | 7.6 | 8.3 | 8.0 | 7.6 | 7.4 | 7.0 |
| Hm     | 1.30Hm  | 1.30Hm  | 4.0  | 9.7               | 9.2  | 8.8 | 8.5 | 9.5  | 9.0 | 8.7 | 8.3 | 9.0 | 8.7 | 8.4 | 8.1 | 8.7 | 8.4 | 8.1 | 7.9 | 7.5 |
|        |         |         | 5.0  | 9.9               | 9.5  | 9.1 | 8.8 | 9.6  | 9.3 | 9.0 | 8.7 | 9.2 | 9.0 | 8.7 | 8.4 | 8.9 | 8.6 | 8.4 | 8.2 | 7.8 |
|        |         |         | 7.0  | 10.1              | 9.8  | 9.5 | 9.3 | 9.9  | 9.6 | 9.4 | 9.2 | 9.5 | 9.3 | 9.1 | 8.9 | 9.1 | 8.9 | 8.8 | 8.6 | 8.2 |
|        |         |         | 10.0 | 10.3              | 10.1 | 9.9 | 9.7 | 10.1 | 9.9 | 9.7 | 9.5 | 9.7 | 9.5 | 9.4 | 9.2 | 9.3 | 9.2 | 9.0 | 8.9 | 8.5 |

