

屋内照明器具特性

品番 (品名)	XAD3 1 3 1 L K	
光源	LLD3 0 2 0 MLCB1 ×1	7 1 5 . 0 1 m
管理番号	K0 1 7 5 5 2 7 (0) DR 1	
B Z 分類	B Z 1	

器具効率	73 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束 0 %		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	73 %	床		10 %				10 %				10 %				10 %				0 %
室指数	照明率 (X 0 . 0 1)																			Z C M
保守率	良	0.67	0.6	60	56	53	51	60	55	53	51	59	55	52	51	58	54	52	50	50
	中	0.63	0.8	65	60	58	56	64	60	58	56	63	60	57	55	62	59	57	55	54
	否	0.56	1.0	67	64	61	59	67	63	61	59	65	63	60	59	64	62	60	58	57
下方投影面積	等価発光面積	c m ²	1.25	70	66	64	62	69	66	64	62	68	65	63	62	66	64	63	61	60
			1.5	71	68	66	64	70	68	66	64	69	67	65	64	68	66	64	63	62
取付高さ	器具間隔最大限		2.5	74	72	71	69	73	72	70	69	72	70	69	68	71	69	68	67	66
	横方向 (A)	縦方向 (B)	3.0	75	73	72	71	74	73	71	70	73	71	70	69	71	70	69	68	67
H m	0.41 H m	0.41 H m	4.0	76	75	73	72	75	74	73	72	74	73	72	71	72	71	71	70	68
			5.0	76	75	74	73	76	75	74	73	74	73	73	72	73	72	71	71	69
			7.0	77	76	76	75	76	76	75	74	75	74	74	73	73	73	72	72	70
			10.0	78	77	76	76	77	76	76	75	75	75	74	74	74	73	73	73	71

