

屋内照明器具特性

品番 (品名)	XAD1200V									
光源	LLD2000VCS1 ×1					580.0 lm				
管理番号	K0181860(0)DR1									
BZ分類	BZ4/0.9/BZ3									

器具効率	83%	天井	80%				70%				50%				30%				0%	
		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0%	
上方光束	0%	床	10%				10%				10%				10%				0%	
下方光束	83%	室指数	照明率 (X0.01)																ZCM	
保守率	良	0.67	0.6	50	41	35	31	49	40	35	31	47	40	34	31	46	39	34	30	29
	中	0.63	0.8	59	50	44	40	58	50	44	40	56	49	44	40	54	48	43	40	38
	否	0.56	1.0	64	57	51	47	63	56	51	47	61	55	50	46	59	54	49	46	44
			1.25	69	62	57	53	68	61	57	53	66	60	56	52	64	59	55	52	50
下方投影面積		cm ²	1.5	72	66	61	57	71	65	61	57	69	64	60	57	67	63	59	56	54
等価発光面積		cm ²	2.0	77	71	67	64	75	71	67	64	73	69	66	63	71	68	65	62	60
取付高さ	器具間隔最大限		2.5	79	75	71	68	78	74	71	68	76	72	69	67	74	71	68	66	64
	横方向 (A)	縦方向 (B)	3.0	81	77	74	71	80	76	73	71	78	75	72	70	75	73	71	69	67
Hm	1.26Hm	1.26Hm	4.0	83	80	78	75	82	79	77	75	80	78	76	74	78	76	74	73	71
			5.0	84	82	80	78	83	81	79	77	81	79	78	76	79	78	76	75	73
			7.0	86	84	83	81	85	83	82	80	83	81	80	79	81	80	79	78	75
			10.0	87	86	85	83	86	85	84	83	84	83	82	81	82	81	80	80	77

