

屋内照明器具特性

品番 (品名)	L G W 8 5 2 3 9 Y									
光源	LLD4000LCE1 ×1					845.0 lm				
管理番号	K0180432 (0) DR 1									
B Z 分類	B Z 5									

器具効率	54 %	天井	80 %				70 %				50 %				30 %				0 %		
	上方光束		5 %	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
	下方光束		49 %		床	10 %				10 %				10 %				10 %			
室指数	照明率 (X 0.01)																			Z C M	
保守率	良	0.63	0.6	30	23	19	16	29	22	18	16	27	22	18	15	25	21	17	15	14	
	中	0.6	0.8	35	28	24	21	34	28	24	21	32	27	23	20	30	25	22	20	18	
	否	0.56	1.0	38	32	28	25	37	32	28	25	35	30	27	24	33	29	26	23	22	
	下方投影面積	c m ²		1.25	41	36	32	29	40	35	31	28	38	34	30	28	36	32	29	27	25
等価発光面積	c m ²		1.5	43	38	35	32	42	38	34	31	40	36	33	30	38	34	32	30	28	
取付高さ	器具間隔最大限		2.0	46	42	39	36	45	41	38	35	43	39	37	34	40	38	35	33	31	
	H m	横方向 (A)	縦方向 (B)	2.5	48	45	42	39	47	44	41	38	44	42	39	37	42	40	38	36	34
1.24 H m		1.24 H m	3.0	50	46	44	41	48	45	43	41	46	43	41	39	43	41	40	38	36	
4.0	51	49	46	44	50	48	46	44	48	46	44	42	45	44	42	41	41	41	41	38	
5.0	52	50	48	46	51	49	47	46	49	47	45	44	46	45	44	44	44	44	43	40	
7.0	54	52	50	49	52	51	49	48	50	49	47	46	48	47	46	46	47	46	45	42	
10.0	55	53	52	51	53	52	51	50	51	50	49	48	49	48	48	48	47	47	47	44	

