

屋内照明器具特性

品番 (品名)	L G W 8 5 2 3 9 Y															
光源	L L D 3 0 2 0 M L C B 1 × 1 7 1 5 . 0 l m															
管理番号	K 0 1 8 0 4 3 8 (0) D R 1															
B Z 分類	B Z 5															

器具効率	50 %	天井	80 %				70 %				50 %				30 %				0 %		
			反射率	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
				床	10 %				10 %				10 %				10 %				0 %
上方光束	4 %	室指数	照明率 (X 0 . 0 1)																Z C M		
下方光束	46 %																				
保守率	良 中 否 0.63 0.6 0.56	0.6	27	21	17	14	26	21	17	14	25	20	16	14	23	19	16	14	12		
		0.8	32	26	22	19	31	25	22	19	29	24	21	18	27	23	20	18	17		
		1.0	35	30	26	22	34	29	25	22	32	28	24	22	30	26	24	21	20		
		1.25	38	33	29	26	37	32	29	26	35	31	28	25	33	29	27	24	23		
下方投影面積	c m ²	1.5	40	35	32	29	39	35	31	28	37	33	30	28	35	32	29	27	25		
		2.0	43	39	36	33	42	38	35	32	40	36	34	31	37	35	33	31	29		
取付高さ	器具間隔最大限		2.5	45	41	38	36	44	40	38	35	41	39	36	34	39	37	35	33		
	横方向 (A)	縦方向 (B)	3.0	46	43	40	38	45	42	39	37	43	40	38	36	40	38	37	35		
H m	1.20 H m	1.20 H m	4.0	48	45	43	41	47	44	42	40	44	42	41	39	42	41	39	38		
			5.0	49	47	45	43	48	46	44	42	45	44	42	41	43	42	41	40	37	
			7.0	50	48	47	45	49	47	46	45	47	45	44	43	45	44	43	39		
			10.0	51	50	49	48	50	49	48	47	48	47	46	45	46	45	44	41		

