

屋内照明器具特性

品番 (品名)	XAD3 1 3 2 L K	
光源	LLD3 0 2 0 MLCB1 ×1	7 1 5 . 0 1 m
管理番号	K0175545 (0) DR 1	
B Z 分類	B Z 1	

器具効率	73 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束 0 %		反射率	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	73 %	床		10 %				10 %				10 %				10 %				0 %
室指数	照明率 (X 0 . 0 1)																			Z C M
保守率	良 0.67	0.6	61	56	53	51	60	56	53	51	59	55	53	51	58	55	53	51	50	
	中 0.63		0.8	65	61	58	56	64	61	58	56	63	60	58	56	62	59	57	56	55
	否 0.56		1.0	68	64	61	60	67	64	61	59	66	63	61	59	65	62	60	59	58
下方投影面積 等価発光面積	c m ²	1.25	70	67	64	62	69	66	64	62	68	65	63	62	67	65	63	62	60	
		1.5	71	68	66	65	71	68	66	64	69	67	65	64	68	66	65	63	62	
取付高さ	器具間隔最大限		2.5	74	72	71	69	73	72	70	69	72	71	69	68	71	69	68	67	66
	横方向 (A)	縦方向 (B)	3.0	75	73	72	71	74	73	71	70	73	71	70	69	71	70	69	69	67
H m	0.41 H m	0.41 H m	4.0	76	75	73	72	75	74	73	72	74	73	72	71	72	71	71	70	68
			5.0	76	75	74	74	76	75	74	73	74	73	73	72	73	72	71	71	69
			7.0	77	76	76	75	76	76	75	74	75	74	74	73	73	73	72	72	70
			10.0	78	77	76	76	77	76	76	75	75	75	74	74	74	73	73	71	

