

屋内照明器具特性

品番 (品名)	XNS 2030 WWK															
光源	LED4000_85_1990 x1 1990.0 lm															
管理番号	K0183321(0)DB1															
BZ分類	BZ1															

器具効率	100%	天井	80%				70%				50%				30%				0%	
		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0%	
上方光束	0%	床	10%				10%				10%				10%				0%	
下方光束	100%	室指数	照明率 (X0.01) ZCM																	
保守率	良 中 否	0.81	0.6	73	65	60	56	73	65	59	56	71	64	59	56	69	63	59	56	54
		0.77	0.8	82	75	70	66	81	75	70	66	80	74	69	66	78	73	69	66	64
		0.68	1.0	88	81	77	73	87	81	76	73	85	80	76	73	83	78	75	72	71
			1.25	92	87	82	79	91	86	82	79	89	85	81	78	87	83	80	78	76
下方投影面積	c m ²	1.5	95	90	86	83	94	89	85	83	92	88	85	82	90	86	84	81	80	
		2.0	98	94	91	88	97	93	90	88	95	92	89	87	93	90	88	86	84	
取付高さ	器具間隔最大限		2.5	100	97	94	92	99	96	93	91	97	94	92	90	95	93	91	89	87
	横方向 (A)	縦方向 (B)	3.0	102	99	96	94	101	98	96	94	98	96	94	92	96	94	93	91	89
H m	1.24 H m	1.24 H m	4.0	103	101	99	97	102	100	98	97	100	98	97	95	98	96	95	94	92
			5.0	104	103	101	99	103	102	100	99	101	100	98	97	99	98	97	96	93
			7.0	106	104	103	102	104	103	102	101	102	101	100	99	100	99	98	98	95
			10.0	106	105	104	104	105	104	103	103	103	102	102	101	101	100	100	99	96

