

屋内照明器具特性

品番 (品名)	XAD5 1 2 1 V	
光源	LLD5 0 2 0 VCC1 × 1	1 0 8 5 . 0 1 m
管理番号	K0187677 (2) DR 1	
BZ分類	BZ1	

器具効率	82 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束		0 %	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	82 %	床	10 %				10 %				10 %				10 %				0 %	
室指数	照明率 (X 0 . 0 1)																			ZCM
保守率	良	0.67	0.6	66	60	57	54	65	60	57	54	64	60	56	54	63	59	56	54	53
	中	0.63	0.8	71	66	63	61	71	66	63	60	69	65	62	60	68	65	62	60	59
	否	0.56	1.0	75	70	67	65	74	70	67	65	73	69	66	64	71	68	66	64	63
下方投影面積	等価発光面積	cm ²	1.25	78	74	71	68	77	73	70	68	75	72	70	68	74	71	69	67	66
			1.5	79	76	73	71	79	75	73	71	77	74	72	70	76	73	71	70	69
取付高さ	器具間隔最大限		2.5	83	81	79	77	82	80	78	77	81	79	77	76	79	78	76	75	73
	横方向 (A)	縦方向 (B)	3.0	84	82	80	79	83	81	80	78	82	80	79	77	80	79	77	76	75
H _m	0.45 H _m	0.45 H _m	4.0	85	84	82	81	84	83	82	80	83	81	80	79	81	80	79	78	76
			5.0	86	85	84	82	85	84	83	82	83	82	81	81	82	81	80	79	77
			7.0	87	86	85	84	86	85	84	83	84	83	83	82	82	82	81	81	79
			10.0	87	87	86	85	86	86	85	85	85	84	84	83	83	82	82	82	79

