

屋内照明器具特性

品番 (品名)	XAS 5 5 2 1 V	
光源	LLD5020VCC1 ×1	1085.0 l m
管理番号	K0187901 (0) DR 1	
BZ分類	BZ1	

器具効率	78 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束 0 %		反射率	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	78 %	床		10 %				10 %				10 %				10 %				0 %
室指数	照明率 (X0.01)																			ZCM
保守率	良 0.67	0.6	64	59	56	54	64	59	56	54	63	58	56	53	62	58	55	53	53	
	中 0.63	0.8	69	65	62	60	69	64	62	59	67	64	61	59	66	63	61	59	58	
	否 0.56	1.0	72	68	66	63	72	68	65	63	70	67	65	63	69	66	64	63	62	
下方投影面積 等価発光面積	c m ²	1.25	75	71	69	67	74	71	68	67	73	70	68	66	71	69	67	66	65	
		1.5	77	74	71	69	76	73	71	69	74	72	70	68	73	71	69	68	67	
取付高さ	器具間隔最大限		2.5	80	78	76	75	79	77	76	74	78	76	75	73	76	75	74	73	71
	横方向 (A)	縦方向 (B)	3.0	81	79	77	76	80	78	77	76	78	77	76	75	77	76	75	74	72
H m	0.44 H m	0.44 H m	4.0	82	80	79	78	81	80	78	77	79	78	77	76	78	77	76	75	74
			5.0	82	81	80	79	82	80	80	79	80	79	78	77	78	78	77	76	74
			7.0	83	82	81	81	82	81	81	80	81	80	79	79	79	78	78	77	75
			10.0	84	83	82	82	83	82	82	81	81	81	80	80	79	79	79	78	76

