

屋内照明器具特性	
品番 (品名)	LAMP _ FDL 27 EX - N
光源	FDL 27 EX - N ×1 1550.0 lm
管理番号	K0019386 (*) DJ 1
BZ分類	BZ10

器具効率		1 0 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
上方光束		4 7 %	室指数	照明率 (X 0 . 0 1)																	Z C M
下方光束		5 3 %																			
保守率		良 中 否	0 . 7 2	0 . 6	4 3	3 0	2 2	1 6	3 9	2 8	2 0	1 5	3 2	2 3	1 7	1 2	2 6	1 8	1 3	9	4
			0 . 7	0 . 8	5 1	3 8	3 0	2 3	4 7	3 5	2 7	2 1	3 8	2 9	2 3	1 8	3 1	2 4	1 8	1 4	8
			0 . 6 6	1 . 0	5 7	4 5	3 6	2 9	5 2	4 1	3 3	2 7	4 3	3 4	2 7	2 2	3 4	2 7	2 2	1 8	1 0
				1 . 2 5	6 3	5 1	4 2	3 5	5 7	4 7	3 9	3 3	4 7	3 9	3 3	2 7	3 8	3 2	2 6	2 2	1 3
下方投影面積		c m ²	1 . 5	6 7	5 6	4 7	4 0	6 1	5 1	4 4	3 7	5 1	4 3	3 7	3 1	4 1	3 5	3 0	2 6	1 6	
等価発光面積			c m ²	2 . 0	7 3	6 3	5 5	4 8	6 7	5 8	5 1	4 5	5 5	4 9	4 3	3 8	4 5	4 0	3 5	3 1	2 0
取付 高さ	器具間隔最大限		2 . 5	7 6	6 8	6 0	5 4	7 0	6 3	5 6	5 0	5 9	5 3	4 7	4 3	4 8	4 3	3 9	3 5	2 3	
	横方向 (A)		縦方向 (B)	3 . 0	7 9	7 1	6 5	5 9	7 3	6 6	6 0	5 5	6 1	5 6	5 1	4 7	5 0	4 6	4 2	3 9	2 6
H m	2 . 5 0 H m	2 . 5 2 H m	4 . 0	8 3	7 6	7 1	6 5	7 7	7 1	6 6	6 1	6 5	6 0	5 6	5 2	5 3	5 0	4 6	4 3	3 0	
			5 . 0	8 5	8 0	7 5	7 0	7 9	7 4	6 9	6 5	6 7	6 3	5 9	5 6	5 6	5 2	4 9	4 7	3 3	
			7 . 0	8 8	8 4	8 0	7 6	8 2	7 8	7 4	7 1	7 0	6 7	6 4	6 1	5 8	5 6	5 3	5 1	3 7	
			1 0 . 0	9 1	8 7	8 4	8 1	8 4	8 1	7 8	7 6	7 2	7 0	6 7	6 5	6 1	5 9	5 7	5 5	4 0	

