

屋内照明器具特性

品番 (品名)	NYM20223 + NYK00111	
光源	LED5000_85_22250 ×1 22250.0 1 m	
管理番号	K0185727 (0) DB 1	
BZ分類	BZ2 / 0.9 / BZ3	

器具効率	100 %	天井	80 %				70 %				50 %				30 %				0 %	
		壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %	
上方光束	6 %	床	10 %				10 %				10 %				10 %				0 %	
下方光束	94 %	室指数	照明率 (X0.01)																ZCM	
保守率	良 中 否	0.77	0.6	65	55	49	45	64	55	49	44	61	53	48	44	59	52	47	43	41
		0.72	0.8	74	65	59	54	73	64	58	54	70	62	57	53	67	61	56	53	50
			1.0	80	72	65	61	78	70	65	60	75	68	64	60	72	67	62	59	56
		0.68	1.25	85	77	72	67	83	76	71	67	80	74	69	66	77	72	68	65	62
下方投影面積	c m ²	1.5	88	81	76	72	86	80	75	71	83	78	73	70	80	75	72	69	66	
		2.0	93	87	82	78	91	85	81	78	87	83	79	76	84	80	77	74	71	
取付高さ	器具間隔最大限		2.5	95	90	86	83	93	89	85	82	90	86	83	80	86	83	81	78	75
	横方向 (A)	縦方向 (B)	3.0	97	93	89	86	95	91	88	85	92	88	86	83	88	86	83	81	78
H m	1.10 H m	1.10 H m	4.0	100	96	93	90	98	95	92	89	94	92	89	87	91	89	87	85	81
			5.0	101	98	96	93	99	97	94	92	96	93	91	90	92	90	89	87	83
			7.0	103	101	99	97	101	99	97	95	97	96	94	93	94	93	91	90	86
			10.0	104	102	101	100	102	101	99	98	99	97	96	95	95	94	93	93	88

