

# 屋内照明器具特性

|         |  |  |
|---------|--|--|
| 品番 (品名) | P A 0 7 5 2 0 W W W P 2 7 + N T S 9 0 2 0 0                        |  |
| 光源      | L E D 2 7 0 0 _ 7 0 _ 2 0 0 × 1                      2 0 0 . 0 1 m |  |
| 管理番号    | K 0 1 5 6 4 5 2 ( 2 ) D B 1  |  |
| B Z 分類  | B Z 1  |  |

|        |                  |          |                   |      |     |     |      |      |     |     |      |      |     |     |      |      |    |    |       |     |
|--------|------------------|----------|-------------------|------|-----|-----|------|------|-----|-----|------|------|-----|-----|------|------|----|----|-------|-----|
| 器具効率   | 100 %            | 天井       | 80 %              |      |     |     | 70 % |      |     |     | 50 % |      |     |     | 30 % |      |    |    | 0 %   |     |
|        |                  |          | 70                | 50   | 30  | 10  | 70   | 50   | 30  | 10  | 70   | 50   | 30  | 10  | 70   | 50   | 30 | 10 | 0 %   |     |
| 上方光束   | 1 %              | 反射率      | 壁                 | 10 % |     |     |      | 10 % |     |     |      | 10 % |     |     |      | 10 % |    |    |       | 0 % |
| 下方光束   | 99 %             |          | 床                 | 10 % |     |     |      | 10 % |     |     |      | 10 % |     |     |      | 10 % |    |    |       | 0 % |
|        |                  | 室指数      | 照明率 ( X 0 . 0 1 ) |      |     |     |      |      |     |     |      |      |     |     |      |      |    |    | Z C M |     |
| 保守率    | 良                | 0.63     | 0.6               | 72   | 63  | 57  | 53   | 70   | 62  | 57  | 53   | 69   | 61  | 56  | 53   | 67   | 60 | 56 | 53    | 51  |
|        | 中                | 0.6      | 0.8               | 80   | 73  | 67  | 63   | 79   | 72  | 67  | 63   | 77   | 71  | 66  | 63   | 75   | 70 | 66 | 63    | 61  |
|        | 否                | 0.56     | 1.0               | 86   | 79  | 74  | 70   | 85   | 78  | 73  | 70   | 82   | 77  | 73  | 69   | 80   | 76 | 72 | 69    | 67  |
| 下方投影面積 | c m <sup>2</sup> | 1.25     | 90                | 84   | 80  | 76  | 89   | 83   | 79  | 76  | 87   | 82   | 78  | 75  | 85   | 81   | 77 | 75 | 73    |     |
|        |                  | 1.5      | 93                | 88   | 84  | 81  | 92   | 87   | 83  | 80  | 90   | 86   | 82  | 79  | 88   | 84   | 81 | 79 | 77    |     |
| 等価発光面積 | c m <sup>2</sup> | 2.0      | 97                | 93   | 89  | 86  | 96   | 92   | 89  | 86  | 93   | 90   | 87  | 85  | 91   | 88   | 86 | 84 | 82    |     |
|        |                  | 2.5      | 99                | 96   | 93  | 90  | 98   | 95   | 92  | 90  | 96   | 93   | 90  | 88  | 93   | 91   | 89 | 87 | 85    |     |
| 取付高さ   | 器具間隔最大限          |          | 3.0               | 101  | 98  | 95  | 93   | 100  | 97  | 94  | 92   | 97   | 95  | 93  | 91   | 95   | 93 | 91 | 87    |     |
|        | 横方向 (A)          | 縦方向 (B)  | 4.0               | 103  | 100 | 98  | 96   | 101  | 99  | 97  | 95   | 99   | 97  | 95  | 94   | 97   | 95 | 94 | 92    |     |
| H m    | 0.65 H m         | 0.85 H m | 5.0               | 104  | 102 | 100 | 98   | 102  | 101 | 99  | 97   | 100  | 98  | 97  | 96   | 98   | 96 | 95 | 94    |     |
|        |                  |          | 7.0               | 105  | 104 | 102 | 101  | 104  | 102 | 101 | 100  | 101  | 100 | 99  | 98   | 99   | 98 | 97 | 96    |     |
|        |                  |          | 10.0              | 106  | 105 | 104 | 103  | 105  | 104 | 103 | 102  | 102  | 101 | 101 | 100  | 100  | 99 | 98 | 95    |     |

