

屋内照明器具特性

| | | | | | | | | | | |
|---------|---|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | XLF216NNNC(JYOUJI_CEILIN) | | | | | | | | | |
| 光源 | LED5000_85_1550 x1 1550.0lm | | | | | | | | | |
| 管理番号 | K0153232(4)DB1 | | | | | | | | | |
| BZ分類 | BZ6/0.7/BZ5/3.5/BZ6/4.5/BZ5 /6.0/BZ6 | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--------|------------------|---------|------|-----|----|----|-----|----|----|----|-----|----|----|----|-----|----|----|----|----|-------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|-----|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 器具効率 | 100% | 天井 | 80% | | | | 70% | | | | 50% | | | | 30% | | | | 0% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 床 | 10% | | | | 10% | | | | 10% | | | | 10% | | | | 0% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 上方光束 | 9% | 室指数 | | | | | | | | | | | | | | | | | | 照明率 (X0.01) | | | | | | | | | | | | | | | | | | ZCM | | | | | | | | | | | | | | | | | |
| 下方光束 | 91% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 中 否 | 0.83 | 0.6 | 53 | 41 | 33 | 27 | 52 | 40 | 32 | 27 | 48 | 38 | 31 | 26 | 45 | 36 | 30 | 26 | 23 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 0.81 | 0.8 | 63 | 51 | 43 | 37 | 61 | 50 | 42 | 36 | 57 | 47 | 41 | 35 | 54 | 45 | 39 | 35 | 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 0.77 | 1.0 | 69 | 58 | 50 | 44 | 67 | 57 | 49 | 43 | 63 | 54 | 47 | 42 | 59 | 51 | 46 | 41 | 38 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | 1.25 | 75 | 65 | 57 | 51 | 73 | 63 | 56 | 50 | 68 | 60 | 54 | 49 | 64 | 57 | 52 | 47 | 44 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 下方投影面積 | c m ² | 1.5 | 79 | 70 | 62 | 56 | 77 | 68 | 61 | 55 | 72 | 65 | 59 | 54 | 68 | 62 | 56 | 52 | 48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 2.0 | 85 | 77 | 70 | 64 | 82 | 75 | 69 | 63 | 78 | 71 | 66 | 61 | 73 | 68 | 63 | 59 | 55 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 等価発光面積 | c m ² | 2.5 | 89 | 81 | 75 | 70 | 86 | 79 | 74 | 69 | 81 | 76 | 71 | 67 | 77 | 72 | 68 | 65 | 60 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | 3.0 | 91 | 85 | 79 | 74 | 89 | 83 | 78 | 73 | 84 | 79 | 75 | 71 | 79 | 75 | 72 | 68 | 64 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 取付高さ | 器具間隔最大限 | | 4.0 | 94 | 89 | 85 | 80 | 92 | 87 | 83 | 79 | 87 | 83 | 80 | 76 | 83 | 80 | 77 | 74 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 横方向 (A) | 縦方向 (B) | 5.0 | 97 | 92 | 88 | 84 | 94 | 90 | 86 | 83 | 89 | 86 | 83 | 80 | 85 | 82 | 80 | 77 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1.5m | 1.94m | 1.91m | 7.0 | 99 | 96 | 92 | 89 | 97 | 94 | 91 | 88 | 92 | 89 | 87 | 85 | 88 | 86 | 84 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 2.58 | 2.51 | 10.0 | 101 | 98 | 96 | 94 | 99 | 96 | 94 | 92 | 94 | 92 | 90 | 89 | 90 | 88 | 87 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2.5 | 3.23 | 3.11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 3.87 | 3.65 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

