

屋内照明器具特性	
品番 (品名)	S L B 1 5 1 4 2 W
光源	LDA7 L - D - G / S / Z 6 × 1 8 1 0 . 0 l m
管理番号	K 0 1 7 2 5 9 1 (0) D B 1
B Z 分類	B Z 5

器具効率		4 6 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1) Z C M																
保守率		良 中 否	0 . 6 3	0 . 6	2 6	2 1	1 7	1 4	2 6	2 0	1 7	1 4	2 4	2 0	1 7	1 4	2 3	1 9	1 6	1 4	1 3
			0 . 6	0 . 8	3 1	2 6	2 2	1 9	3 0	2 5	2 2	1 9	2 9	2 5	2 1	1 9	2 8	2 4	2 1	1 9	1 8
			0 . 5 6	1 . 0	3 4	2 9	2 5	2 3	3 3	2 9	2 5	2 3	3 2	2 8	2 5	2 3	3 1	2 7	2 5	2 2	2 1
				1 . 2 5	3 7	3 2	2 9	2 6	3 6	3 2	2 9	2 6	3 4	3 1	2 8	2 6	3 3	3 0	2 8	2 6	2 5
下方投影面積		c m ²		1 . 5	3 9	3 5	3 1	2 9	3 8	3 4	3 1	2 9	3 6	3 3	3 1	2 8	3 5	3 2	3 0	2 8	2 7
			等価発光面積	c m ²	2 . 0	4 1	3 8	3 5	3 3	4 0	3 7	3 5	3 3	3 9	3 6	3 4	3 2	3 8	3 5	3 4	3 2
取付 高さ	器具間隔最大限			2 . 5	4 3	4 0	3 7	3 5	4 2	3 9	3 7	3 5	4 1	3 8	3 6	3 5	3 9	3 7	3 6	3 4	3 3
	横方向 (A) 縦方向 (B)			3 . 0	4 4	4 1	3 9	3 7	4 3	4 1	3 9	3 7	4 2	4 0	3 8	3 7	4 1	3 9	3 7	3 6	3 5
H m	1 . 2 6 H m	1 . 2 6 H m		4 . 0	4 5	4 3	4 2	4 0	4 5	4 3	4 1	4 0	4 3	4 2	4 0	3 9	4 2	4 1	4 0	3 9	3 7
				5 . 0	4 6	4 5	4 3	4 2	4 5	4 4	4 3	4 1	4 4	4 3	4 2	4 1	4 3	4 2	4 1	4 0	3 9
				7 . 0	4 7	4 6	4 5	4 4	4 6	4 5	4 4	4 3	4 5	4 4	4 3	4 3	4 4	4 3	4 3	4 2	4 1
				1 0 . 0	4 8	4 7	4 6	4 5	4 7	4 6	4 6	4 5	4 6	4 5	4 5	4 4	4 5	4 4	4 4	4 3	4 2

