

屋内照明器具特性	
品番 (品名)	S L B 1 5 7 8 5 + S L K 2 2 0 0 4
光源	L L D 3 4 1 1 L C B 1 × 1 7 0 0 . 0 l m
管理番号	K 0 1 9 2 9 9 6 (0) D B 1
B Z 分類	B Z 1

器具効率		9 8 %	反 射 率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %			
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %			
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %			
上方光束		0 %	室指数	照明率 (X 0 . 0 1)																			Z C M	
下方光束		9 8 %																						
保守率		良	0 . 6 7	0 . 6	8 8	8 3	8 1	7 9	8 7	8 3	8 0	7 8	8 6	8 3	8 0	7 8	8 5	8 2	8 0	7 8	7 7			
		中	0 . 6 3	0 . 8	9 3	8 8	8 6	8 4	9 2	8 8	8 6	8 4	9 1	8 7	8 5	8 3	8 9	8 7	8 5	8 3	8 2			
		否	0 . 5 6	1 . 0	9 5	9 2	8 9	8 7	9 5	9 1	8 9	8 7	9 3	9 0	8 8	8 7	9 2	9 0	8 8	8 6	8 5			
				1 . 2 5	9 7	9 4	9 2	9 0	9 7	9 4	9 2	9 0	9 5	9 3	9 1	8 9	9 4	9 2	9 0	8 9	8 8			
下方投影面積		c m ²		1 . 5	9 9	9 6	9 4	9 2	9 8	9 5	9 3	9 2	9 6	9 4	9 3	9 1	9 5	9 3	9 2	9 1	8 9			
等価発光面積		c m ²		2 . 0	1 0 1	9 8	9 7	9 5	1 0 0	9 8	9 6	9 5	9 8	9 6	9 5	9 4	9 7	9 5	9 4	9 3	9 1			
取付	器具間隔最大限			2 . 5	1 0 2	1 0 0	9 8	9 7	1 0 1	9 9	9 8	9 6	9 9	9 8	9 6	9 5	9 7	9 6	9 5	9 4	9 3			
高さ	横方向 (A)		縦方向 (B)	3 . 0	1 0 3	1 0 1	9 9	9 8	1 0 2	1 0 0	9 9	9 8	1 0 0	9 8	9 7	9 6	9 8	9 7	9 6	9 5	9 3			
H m	0 . 7 6 H m		0 . 7 6 H m	4 . 0	1 0 3	1 0 2	1 0 1	1 0 0	1 0 2	1 0 1	1 0 0	9 9	1 0 0	1 0 0	9 9	9 8	9 9	9 8	9 7	9 7	9 4			
				5 . 0	1 0 4	1 0 3	1 0 2	1 0 1	1 0 3	1 0 2	1 0 1	1 0 0	1 0 1	1 0 0	9 9	9 9	9 9	9 8	9 8	9 7	9 5			
				7 . 0	1 0 5	1 0 4	1 0 3	1 0 2	1 0 4	1 0 3	1 0 2	1 0 1	1 0 2	1 0 1	1 0 0	1 0 0	1 0 0	9 9	9 9	9 8	9 6			
				1 0 . 0	1 0 5	1 0 5	1 0 4	1 0 4	1 0 4	1 0 4	1 0 3	1 0 3	1 0 2	1 0 2	1 0 1	1 0 1	1 0 0	1 0 0	9 9	9 9	9 6			

