

屋内照明器具特性

品番 (品名)	XAD3 1 2 1 K	
光源	LLD3 0 2 0 CU1 × 1	6 1 5 . 0 1 m
管理番号	K0 1 7 8 9 3 9 (0) DR 1	
B Z 分類	B Z 1	

器具効率	83 %	天井	80 %				70 %				50 %				30 %				0 %	
	上方光束		0 %	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
下方光束	83 %	床	10 %				10 %				10 %				10 %				0 %	
室指数			照明率 (X 0 . 0 1)																Z C M	
保守率	良	0.67	0.6	71	66	63	61	70	66	63	61	69	65	62	61	68	65	62	60	60
	中	0.63	0.8	75	71	68	66	74	71	68	66	73	70	67	65	72	69	67	65	64
	否	0.56	1.0	78	74	71	69	77	74	71	69	76	73	71	69	75	72	70	69	67
下方投影面積	等価発光面積	c m ²	1.25	80	77	74	72	80	76	74	72	78	76	73	72	77	75	73	71	70
			1.5	82	79	77	75	81	78	76	74	80	77	75	74	78	76	75	73	72
取付高さ	器具間隔最大限		2.0	84	81	79	78	83	81	79	77	81	80	78	77	80	78	77	76	75
	横方向 (A)	縦方向 (B)	2.5	85	83	81	80	84	82	81	79	83	81	80	79	81	80	79	78	76
H m	0.36 H m	0.36 H m	3.0	86	84	83	81	85	83	82	81	83	82	81	80	82	81	80	79	77
			4.0	87	85	84	83	86	85	84	83	84	83	82	81	83	82	81	80	78
			5.0	87	86	85	84	87	86	85	84	85	84	83	82	83	82	82	81	79
			7.0	88	87	86	86	87	86	86	85	85	85	84	84	84	83	83	82	80
			10.0	89	88	87	87	88	87	87	86	86	85	85	85	84	84	83	83	81

