

# 屋内照明器具特性

|         |                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|---------|--------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | LGB16133                 |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 光源      | LLD5000LCC1 ×1 1140.0 lm |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 管理番号    | K0190443(0)DR1           |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| BZ分類    | BZ3                      |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

|        |                                     |          |      |                 |    |    |     |     |    |    |     |     |    |    |     |     |    |    |    |    |
|--------|-------------------------------------|----------|------|-----------------|----|----|-----|-----|----|----|-----|-----|----|----|-----|-----|----|----|----|----|
| 器具効率   | 96%                                 | 天井       | 80%  |                 |    |    | 70% |     |    |    | 50% |     |    |    | 30% |     |    |    | 0% |    |
|        |                                     |          | 壁    | 70              | 50 | 30 | 10  | 70  | 50 | 30 | 10  | 70  | 50 | 30 | 10  | 70  | 50 | 30 | 10 | 0% |
| 上方光束   | 1%                                  | 反射率      | 床    | 10%             |    |    |     | 10% |    |    |     | 10% |    |    |     | 10% |    |    |    | 0% |
| 下方光束   | 95%                                 |          | 室指数  | 照明率 (X0.01) ZCM |    |    |     |     |    |    |     |     |    |    |     |     |    |    |    |    |
| 保守率    | 良<br>中<br>否<br>0.67<br>0.63<br>0.56 | 0.6      | 62   | 52              | 45 | 41 | 60  | 51  | 45 | 41 | 58  | 50  | 44 | 40 | 56  | 49  | 44 | 40 | 39 |    |
|        |                                     | 0.8      | 71   | 62              | 56 | 52 | 70  | 62  | 56 | 51 | 68  | 60  | 55 | 51 | 66  | 59  | 54 | 51 | 49 |    |
|        |                                     | 1.0      | 77   | 69              | 63 | 59 | 76  | 68  | 63 | 59 | 74  | 67  | 62 | 58 | 71  | 66  | 61 | 58 | 56 |    |
|        |                                     | 1.25     | 82   | 75              | 70 | 66 | 81  | 74  | 69 | 65 | 79  | 73  | 68 | 65 | 76  | 71  | 67 | 64 | 62 |    |
| 下方投影面積 | c m <sup>2</sup>                    | 1.5      | 86   | 79              | 74 | 70 | 84  | 78  | 74 | 70 | 82  | 77  | 73 | 69 | 79  | 75  | 72 | 69 | 67 |    |
|        |                                     | 2.0      | 90   | 85              | 81 | 77 | 89  | 84  | 80 | 77 | 86  | 82  | 79 | 76 | 84  | 80  | 77 | 75 | 73 |    |
| 取付高さ   | 器具間隔最大限                             |          | 2.5  | 93              | 88 | 85 | 82  | 91  | 87 | 84 | 81  | 89  | 85 | 82 | 80  | 86  | 84 | 81 | 79 | 76 |
|        | 横方向 (A)                             | 縦方向 (B)  | 3.0  | 95              | 91 | 87 | 85  | 93  | 90 | 87 | 84  | 91  | 88 | 85 | 83  | 88  | 86 | 84 | 82 | 79 |
| H m    | 1.26 H m                            | 1.26 H m | 4.0  | 97              | 94 | 91 | 89  | 95  | 93 | 90 | 88  | 93  | 91 | 89 | 87  | 90  | 89 | 87 | 85 | 83 |
|        |                                     |          | 5.0  | 98              | 96 | 93 | 91  | 97  | 95 | 92 | 91  | 94  | 92 | 91 | 89  | 92  | 90 | 89 | 88 | 85 |
|        |                                     |          | 7.0  | 100             | 98 | 96 | 95  | 98  | 97 | 95 | 94  | 96  | 94 | 93 | 92  | 93  | 92 | 91 | 90 | 87 |
|        |                                     |          | 10.0 | 101             | 99 | 98 | 97  | 99  | 98 | 97 | 96  | 97  | 96 | 95 | 94  | 95  | 94 | 93 | 92 | 89 |

