

屋内照明器具特性

| | | |
|---------|--|--|
| 品番 (品名) | SLB16781+SLK22011+SLK290 | |
| 光源 | LLD3401LCB1 ×1 700.0 lm | |
| 管理番号 | K0192481(1)DR1 | |
| BZ分類 | BZ1 | |

| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|----------------|--------------------|--------------------|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|-----|
| 器具効率 | 38% | 天井 | 80% | | | | 70% | | | | 50% | | | | 30% | | | | 0% | | | | | | | | | | | | | | | | | | | | | |
| | | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0% | | | | | | | | | | | | | | | | | | | | | |
| | | 床 | 10% | | | | 10% | | | | 10% | | | | 10% | | | | 0% | | | | | | | | | | | | | | | | | | | | | |
| 上方光束 | 0% | 室指数 | | | | | | | | | | | | | | | | | | | 照明率 (X0.01) | | | | | | | | | | | | | | | | | | | ZCM |
| 下方光束 | 38% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 中 否 | 0.67 | 0.6 | 3.1 | 2.9 | 2.7 | 2.6 | 3.1 | 2.9 | 2.7 | 2.6 | 3.0 | 2.8 | 2.7 | 2.6 | 3.0 | 2.8 | 2.7 | 2.6 | 2.6 | | | | | | | | | | | | | | | | | | | | |
| | | 0.63 | 0.8 | 3.4 | 3.2 | 3.0 | 2.9 | 3.4 | 3.2 | 3.0 | 2.9 | 3.3 | 3.1 | 3.0 | 2.9 | 3.2 | 3.1 | 3.0 | 2.9 | 2.8 | | | | | | | | | | | | | | | | | | | | |
| | | 0.56 | 1.0 | 3.5 | 3.4 | 3.2 | 3.1 | 3.5 | 3.3 | 3.2 | 3.1 | 3.4 | 3.3 | 3.2 | 3.1 | 3.4 | 3.3 | 3.2 | 3.1 | 3.0 | | | | | | | | | | | | | | | | | | | | |
| | | | 1.25 | 3.7 | 3.5 | 3.4 | 3.3 | 3.6 | 3.5 | 3.4 | 3.3 | 3.6 | 3.4 | 3.3 | 3.2 | 3.5 | 3.4 | 3.3 | 3.2 | 3.2 | | | | | | | | | | | | | | | | | | | | |
| 下方投影面積 | c m ² | 1.5 | 3.7 | 3.6 | 3.5 | 3.4 | 3.7 | 3.6 | 3.5 | 3.4 | 3.6 | 3.5 | 3.4 | 3.4 | 3.6 | 3.5 | 3.4 | 3.3 | 3.3 | | | | | | | | | | | | | | | | | | | | | |
| | | 2.0 | 3.8 | 3.7 | 3.6 | 3.5 | 3.8 | 3.7 | 3.6 | 3.5 | 3.7 | 3.6 | 3.6 | 3.5 | 3.7 | 3.6 | 3.5 | 3.5 | 3.4 | | | | | | | | | | | | | | | | | | | | | |
| 取付高さ | 器具間隔最大限 | | 2.5 | 3.9 | 3.8 | 3.7 | 3.6 | 3.9 | 3.8 | 3.7 | 3.6 | 3.8 | 3.7 | 3.6 | 3.7 | 3.6 | 3.6 | 3.5 | 3.5 | | | | | | | | | | | | | | | | | | | | | |
| | 横方向 (A) | 縦方向 (B) | 3.0 | 3.9 | 3.8 | 3.8 | 3.7 | 3.9 | 3.8 | 3.7 | 3.7 | 3.8 | 3.8 | 3.7 | 3.6 | 3.7 | 3.7 | 3.6 | 3.5 | | | | | | | | | | | | | | | | | | | | | |
| H _m | 0.87H _m | 0.86H _m | 4.0 | 4.0 | 3.9 | 3.8 | 3.9 | 3.9 | 3.8 | 3.8 | 3.9 | 3.8 | 3.8 | 3.7 | 3.8 | 3.7 | 3.7 | 3.7 | 3.6 | | | | | | | | | | | | | | | | | | | | | |
| | | | 5.0 | 4.0 | 4.0 | 3.9 | 3.9 | 4.0 | 3.9 | 3.9 | 3.8 | 3.9 | 3.8 | 3.8 | 3.8 | 3.8 | 3.8 | 3.7 | 3.6 | | | | | | | | | | | | | | | | | | | | | |
| | | | 7.0 | 4.0 | 4.0 | 4.0 | 3.9 | 4.0 | 4.0 | 3.9 | 3.9 | 3.9 | 3.9 | 3.9 | 3.9 | 3.8 | 3.8 | 3.8 | 3.7 | | | | | | | | | | | | | | | | | | | | | |
| | | | 10.0 | 4.1 | 4.0 | 4.0 | 4.0 | 4.0 | 4.0 | 4.0 | 4.0 | 3.9 | 3.9 | 3.9 | 3.9 | 3.9 | 3.8 | 3.8 | 3.7 | | | | | | | | | | | | | | | | | | | | | |

