

# 屋内照明器具特性

品番 (品名)	XAS 5500L									
光源	LLD5000LCC1 ×1					1140.0 lm				
管理番号	K0187895(0)DR1									
BZ分類	BZ2									

器具効率	89%	天井	80%				70%				50%				30%				0%		
			反射率	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0%
				床	10%				10%				10%				10%				0%
上方光束	0%	室指数	照明率 ( X0.01 )																ZCM		
下方光束	89%																				
保守率	良 中 否	0.67	0.6	60	51	45	42	59	51	45	42	57	50	45	41	56	49	45	41	40	
		0.63	0.8	69	61	56	52	68	61	56	52	66	60	55	52	64	59	55	51	50	
			1.0	75	68	63	59	74	67	62	59	72	66	62	58	70	65	61	58	57	
		0.56	1.25	79	73	69	65	78	72	68	65	76	71	67	64	74	70	67	64	62	
下方投影面積	c m <sup>2</sup>	1.5	82	77	72	69	81	76	72	69	79	75	71	68	77	73	70	68	66		
		2.0	86	81	78	75	85	81	77	74	82	79	76	74	80	78	75	73	71		
取付高さ	器具間隔最大限		2.5	88	84	81	79	87	84	81	78	85	82	79	77	83	80	78	76	74	
	横方向 (A)	縦方向 (B)	3.0	90	86	84	81	88	85	83	81	86	84	82	80	84	82	80	79	77	
H m	1.25 H m	1.25 H m	4.0	91	89	87	85	90	88	86	84	88	86	84	83	86	85	83	82	80	
			5.0	93	90	89	87	91	90	88	86	89	88	86	85	87	86	85	84	81	
			7.0	94	92	91	90	93	91	90	89	91	89	88	87	89	88	87	86	83	
			10.0	95	94	93	92	94	93	92	91	92	91	90	89	90	89	88	88	85	

