

屋内照明器具特性	
品番 (品名)	S L B 8 0 5 1 0
光源	LDA5 L - D - G - E 1 7 / S / Z 4 × 1 4 4 0 . 0 l m
管理番号	K 0 1 3 9 3 1 3 (0) D R 1
B Z 分類	B Z 4

器具効率		4 1 %	反射率	天井	8 0 %					7 0 %					5 0 %					3 0 %					0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %				
				床	1 0 %					1 0 %					1 0 %					1 0 %					0 %
上方光束		1 0 %	室指数	照明率 (X 0 . 0 1)																				Z C M	
下方光束		3 1 %																							
保守率		良 中 否	0 . 6 7	0 . 6	2 3	1 8	1 5	1 3	2 1	1 7	1 4	1 2	2 0	1 6	1 4	1 2	1 8	1 5	1 3	1 1	1 0				
			0 . 6 3	0 . 8	2 6	2 2	1 9	1 7	2 5	2 1	1 8	1 6	2 3	2 0	1 7	1 6	2 1	1 8	1 6	1 5	1 3				
			1 . 0	2 9	2 5	2 2	2 0	2 8	2 4	2 1	1 9	2 5	2 2	2 0	1 8	2 3	2 1	1 9	1 7	1 5					
			0 . 5 6	1 . 2 5	3 1	2 8	2 5	2 3	3 0	2 7	2 4	2 2	2 7	2 5	2 3	2 1	2 5	2 3	2 1	2 0	1 7				
下方投影面積		c m ²	1 . 5	3 3	3 0	2 7	2 5	3 2	2 9	2 6	2 4	2 9	2 6	2 5	2 3	2 6	2 4	2 3	2 2	1 9					
			等価発光面積	c m ²	2 . 0	3 5	3 2	3 0	2 8	3 4	3 1	2 9	2 7	3 1	2 9	2 7	2 6	2 8	2 7	2 5	2 4	2 1			
取付高さ	器具間隔最大限		2 . 5	3 7	3 4	3 2	3 1	3 5	3 3	3 1	3 0	3 2	3 0	2 9	2 8	2 9	2 8	2 7	2 6	2 3					
	横方向 (A) 縦方向 (B)		3 . 0	3 8	3 5	3 4	3 2	3 6	3 4	3 3	3 1	3 3	3 2	3 0	2 9	3 0	2 9	2 8	2 7	2 4					
H m	1 . 0 9 H m	1 . 4 6 H m	4 . 0	3 9	3 7	3 6	3 4	3 7	3 6	3 4	3 3	3 4	3 3	3 2	3 1	3 1	3 0	3 0	2 9	2 6					
			5 . 0	3 9	3 8	3 7	3 6	3 8	3 7	3 6	3 5	3 5	3 4	3 3	3 2	3 2	3 1	3 1	3 0	2 6					
			7 . 0	4 0	3 9	3 8	3 7	3 9	3 8	3 7	3 6	3 6	3 5	3 4	3 4	3 3	3 2	3 2	3 1	2 8					
			1 0 . 0	4 1	4 0	3 9	3 9	3 9	3 9	3 8	3 7	3 6	3 6	3 5	3 5	3 3	3 3	3 3	3 2	2 8					

