

屋内照明器具特性

| | | | | | | | | | | | | | | | |
|---------|-------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | XF X4 2 0 CEN | | | | | | | | | | | | | | |
| 光源 | LED5000_85_2430 x1 2430.0 1 m | | | | | | | | | | | | | | |
| 管理番号 | K0192157(0)D 1 | | | | | | | | | | | | | | |
| BZ分類 | BZ6 | | | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | | | |
|--------|------------------|---------|---------------|----|------|----|------|----|------|----|------|----|------|----|------|----|------|----|-----|----|-----|-----|
| 器具効率 | 100 % | 天井 | 80 % | | | | 70 % | | | | 50 % | | | | 30 % | | | | 0 % | | | |
| | | | 反射率 | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0 % | |
| | | | | 床 | 10 % | | | | 10 % | | | | 10 % | | | | 10 % | | | | 0 % | |
| 上方光束 | 17 % | 室指数 | 照明率 (X0.01) | | | | | | | | | | | | | | | | | | | ZCM |
| 下方光束 | 83 % | | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 中 否 | 0.83 | 0.6 | 51 | 39 | 31 | 25 | 49 | 37 | 30 | 24 | 45 | 35 | 28 | 23 | 41 | 33 | 27 | 22 | 19 | | |
| | | 0.81 | 0.8 | 60 | 48 | 40 | 34 | 58 | 47 | 39 | 33 | 53 | 44 | 37 | 32 | 49 | 41 | 35 | 30 | 26 | | |
| | | 0.77 | 1.0 | 67 | 55 | 47 | 40 | 64 | 53 | 45 | 39 | 59 | 50 | 43 | 38 | 54 | 46 | 40 | 36 | 32 | | |
| | | | 1.25 | 72 | 62 | 53 | 47 | 69 | 60 | 52 | 46 | 64 | 56 | 49 | 44 | 59 | 52 | 46 | 42 | 37 | | |
| 下方投影面積 | c m ² | 1.5 | 77 | 66 | 59 | 52 | 73 | 64 | 57 | 51 | 68 | 60 | 54 | 49 | 62 | 56 | 51 | 46 | 41 | | | |
| | | 2.0 | 82 | 73 | 66 | 60 | 79 | 71 | 64 | 59 | 73 | 66 | 61 | 56 | 67 | 62 | 57 | 53 | 48 | | | |
| 取付高さ | 器具間隔最大限 | | 2.5 | 86 | 78 | 72 | 66 | 83 | 76 | 70 | 64 | 76 | 71 | 66 | 61 | 71 | 66 | 62 | 58 | 52 | | |
| | 横方向 (A) | 縦方向 (B) | 3.0 | 88 | 82 | 76 | 71 | 85 | 79 | 73 | 69 | 79 | 74 | 69 | 65 | 73 | 69 | 65 | 62 | 55 | | |
| 1.5m | 1.97 m | 2.11 m | 4.0 | 92 | 86 | 81 | 77 | 89 | 83 | 79 | 75 | 82 | 78 | 74 | 71 | 76 | 73 | 70 | 67 | 60 | | |
| 2 | 2.59 | 2.64 | 5.0 | 94 | 89 | 85 | 81 | 91 | 86 | 82 | 79 | 85 | 81 | 78 | 74 | 79 | 76 | 73 | 70 | 64 | | |
| 2.5 | 3.23 | 3.2 | 7.0 | 97 | 93 | 89 | 86 | 93 | 90 | 87 | 84 | 87 | 84 | 82 | 79 | 81 | 79 | 77 | 75 | 68 | | |
| 3 | 3.85 | 3.78 | 10.0 | 99 | 96 | 93 | 91 | 96 | 93 | 90 | 88 | 89 | 87 | 85 | 83 | 84 | 82 | 80 | 79 | 71 | | |

