

屋内照明器具特性

品番 (品名)	XAD5 1 0 1 V	
光源	LLD5000VCC1 ×1	1140.0 lm
管理番号	K0187675 (2) DR 1	
BZ分類	BZ2	

器具効率	80 %	天井	80 %				70 %				50 %				30 %				0 %	
			壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
上方光束	0 %	反射率	10 %				10 %				10 %				10 %				0 %	
下方光束	80 %		床	10 %				10 %				10 %				10 %				0 %
		室指数	照明率 (X0.01)																ZCM	
保守率	良	0.67	0.6	53	46	40	37	53	45	40	37	51	44	40	37	50	44	40	37	35
	中	0.63	0.8	62	55	50	46	61	54	50	46	59	53	49	46	57	52	49	46	44
	否	0.56	1.0	67	61	56	53	66	60	56	53	64	59	55	52	62	58	55	52	51
			1.25	71	66	61	58	70	65	61	58	68	64	60	58	66	63	60	57	56
下方投影面積	cm ²		1.5	74	69	65	62	73	68	65	62	71	67	64	61	69	66	63	61	59
等価発光面積	cm ²		2.0	77	73	70	67	76	72	70	67	74	71	69	66	72	70	68	66	64
取付高さ	器具間隔最大限		2.5	79	76	73	71	78	75	73	70	76	74	72	70	74	72	70	69	67
	横方向 (A)	縦方向 (B)	3.0	80	78	75	73	79	77	75	73	78	75	73	72	76	74	72	71	69
Hm	1.23Hm	1.23Hm	4.0	82	80	78	76	81	79	77	76	79	78	76	75	77	76	75	74	72
			5.0	83	81	80	78	82	80	79	78	80	79	78	76	78	77	76	75	73
			7.0	84	83	82	81	83	82	81	80	81	80	79	79	80	79	78	77	75
			10.0	85	84	83	82	84	83	82	82	82	81	81	80	80	80	79	79	77

