

屋内照明器具特性	
品番 (品名)	X F L 3 2 3 K L
光源	LDL40S. N / 14 / 26 (2 6 0 0 A) × 2 2 6 0 0 . 0 l m
管理番号	K 0 1 2 6 7 6 5 (1) D R 1
B Z 分類	B Z 3

器具効率		7 0 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
				室指数	照明率 (X 0 . 0 1)																Z C M
保守率		良 中 否	0 . 7 7	0 . 6	4 4	3 6	3 1	2 8	4 3	3 6	3 1	2 8	4 2	3 5	3 1	2 8	4 0	3 4	3 1	2 8	2 6
			0 . 7 2	0 . 8	5 1	4 4	3 9	3 5	5 0	4 3	3 9	3 5	4 8	4 2	3 8	3 5	4 7	4 2	3 8	3 5	3 4
			0 . 6 8	1 . 0	5 5	4 9	4 4	4 1	5 4	4 8	4 4	4 1	5 2	4 7	4 3	4 0	5 1	4 6	4 3	4 0	3 9
				1 . 2 5	5 9	5 3	4 9	4 6	5 8	5 3	4 9	4 6	5 6	5 2	4 8	4 5	5 4	5 1	4 7	4 5	4 3
下方投影面積		c m ²		1 . 5	6 2	5 7	5 2	4 9	6 1	5 6	5 2	4 9	5 9	5 5	5 1	4 9	5 7	5 3	5 1	4 8	4 7
			等価発光面積	c m ²	2 . 0	6 5	6 1	5 7	5 4	6 4	6 0	5 7	5 4	6 2	5 9	5 6	5 4	6 0	5 8	5 5	5 3
取付 高さ	器具間隔最大限			2 . 5	6 7	6 4	6 1	5 8	6 6	6 3	6 0	5 8	6 4	6 1	5 9	5 7	6 3	6 0	5 8	5 6	5 5
	横方向 (A) 縦方向 (B)			3 . 0	6 9	6 6	6 3	6 0	6 8	6 5	6 2	6 0	6 6	6 3	6 1	5 9	6 4	6 2	6 0	5 8	5 7
1 . 5 m	1 . 7 6 m	1 . 9 6 m		4 . 0	7 0	6 8	6 6	6 4	7 0	6 7	6 5	6 3	6 8	6 6	6 4	6 2	6 6	6 4	6 3	6 2	6 0
2	2 . 3 3	2 . 4 4		5 . 0	7 2	7 0	6 8	6 6	7 1	6 9	6 7	6 5	6 9	6 7	6 6	6 4	6 7	6 6	6 5	6 3	6 2
2 . 5	2 . 9	2 . 9 4		7 . 0	7 3	7 1	7 0	6 9	7 2	7 1	6 9	6 8	7 0	6 9	6 8	6 7	6 8	6 8	6 7	6 6	6 4
3	3 . 4 7	3 . 4 5		1 0 . 0	7 4	7 3	7 2	7 1	7 3	7 2	7 1	7 0	7 1	7 0	7 0	6 9	7 0	6 9	6 8	6 8	6 6

