

屋内照明器具特性

品番 (品名)	XAS 3502														
光源	LLD3000CU1 x1 795.0 lm														
管理番号	K0178920(0)DR1														
BZ分類	BZ4														

器具効率	89%	天井	80%				70%				50%				30%				0%	
			壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0%
上方光束	0%	反射率	10%				10%				10%				10%				0%	
下方光束	89%		床	10%				10%				10%				10%				0%
		室指数	照明率 (X0.01) ZCM																	
保守率	良	0.67	0.6	53	42	35	31	51	42	35	31	49	41	35	30	47	40	34	30	29
	中	0.63	0.8	62	52	45	41	60	51	45	40	58	50	44	40	56	49	44	40	38
	否	0.56	1.0	68	59	52	48	66	58	52	47	64	57	51	47	62	55	51	47	45
			1.25	73	65	59	54	72	64	59	54	69	63	58	54	67	61	57	53	51
下方投影面積			1.5	77	69	64	59	75	69	63	59	73	67	62	59	70	65	61	58	56
等価発光面積			2.0	81	76	71	67	80	75	70	66	78	73	69	66	75	71	68	65	63
取付高さ	器具間隔最大限		2.5	84	79	75	72	83	78	75	71	81	77	73	70	78	75	72	69	67
	横方向 (A)	縦方向 (B)	3.0	86	82	78	75	85	81	78	75	83	79	76	74	80	77	75	73	70
Hm	1.29Hm	1.29Hm	4.0	89	86	83	80	88	85	82	79	85	83	80	78	83	81	79	77	75
			5.0	91	88	85	83	89	87	84	82	87	85	83	81	85	83	81	80	77
			7.0	92	90	88	86	91	89	87	86	89	87	86	84	87	85	84	83	80
			10.0	94	92	91	89	92	91	90	88	90	89	88	87	88	87	86	85	83

