

屋内照明器具特性	
品番 (品名)	S L B 7 1 5 8 1 B
光源	LDA5 L - D - G - E 1 7 / S / Z 4 × 1 4 4 0 . 0 l m
管理番号	K 0 1 1 1 9 3 3 (2) D B 1
B Z 分類	B Z 7

器具効率		8 4 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %			
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %			
				床	1 0 %				1 0 %				1 0 %				1 0 %				0 %			
上方光束		2 9 %	室指数	照明率 (X 0 . 0 1) Z C M																				
下方光束		5 5 %																						
保守率		良 中 否	0 . 6 3	0 . 6	0 . 6	0 . 5 6	0 . 6	4 0	2 9	2 3	1 8	3 7	2 8	2 1	1 7	3 2	2 5	1 9	1 5	2 8	2 2	1 7	1 4	1 0
			0 . 6	0 . 8	4 7	3 7	3 0	2 5	4 4	3 5	2 8	2 3	3 8	3 1	2 5	2 1	3 3	2 7	2 2	1 9	1 4			
			0 . 5 6	1 . 0	5 2	4 2	3 5	3 0	4 9	4 0	3 3	2 8	4 3	3 5	3 0	2 6	3 7	3 1	2 6	2 3	1 8			
				1 . 2 5	5 7	4 8	4 1	3 5	5 3	4 5	3 9	3 4	4 7	4 0	3 5	3 0	4 0	3 5	3 1	2 7	2 1			
下方投影面積		c m ²	1 . 5	6 0	5 2	4 5	4 0	5 7	4 9	4 3	3 8	4 9	4 3	3 8	3 4	4 3	3 8	3 4	3 0	2 4				
等価発光面積			c m ²	2 . 0	6 5	5 8	5 1	4 6	6 1	5 4	4 9	4 4	5 4	4 8	4 4	4 0	4 7	4 2	3 9	3 5	2 8			
取付高さ	器具間隔最大限			2 . 5	6 8	6 2	5 6	5 1	6 4	5 8	5 3	4 9	5 6	5 2	4 7	4 4	4 9	4 5	4 2	3 9	3 1			
横方向 (A)		縦方向 (B)		3 . 0	7 0	6 4	5 9	5 5	6 6	6 1	5 6	5 2	5 9	5 4	5 0	4 7	5 1	4 8	4 5	4 2	3 4			
H m	1 . 4 1 H m	1 . 4 1 H m	4 . 0	7 3	6 8	6 4	6 0	6 9	6 5	6 1	5 7	6 1	5 8	5 4	5 1	5 4	5 1	4 8	4 6	3 7				
			5 . 0	7 5	7 1	6 7	6 4	7 1	6 7	6 4	6 1	6 3	6 0	5 7	5 5	5 6	5 3	5 1	4 9	4 0				
			7 . 0	7 8	7 4	7 1	6 8	7 3	7 0	6 8	6 5	6 5	6 3	6 1	5 9	5 8	5 6	5 4	5 2	4 3				
			1 0 . 0	7 9	7 7	7 4	7 2	7 5	7 3	7 1	6 9	6 7	6 5	6 4	6 2	6 0	5 8	5 7	5 5	4 6				

