

屋内照明器具特性	
品番 (品名)	XAD5 1 0 1 V
光源	LLD5000VCC1 ×1 1140.0 lm
管理番号	K0187675 (2) DR 1
BZ分類	BZ2

器具効率		80 %		反射率	天井	80 %				70 %				50 %				30 %				0 %
					壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
					床	10 %				10 %				10 %				10 %				0 %
					室指数	照明率 (X0.01) ZCM																
保守率		良 中 否	0.67	0.6	53	46	40	37	53	45	40	37	51	44	40	37	50	44	40	37	35	
			0.63	0.8	62	55	50	46	61	54	50	46	59	53	49	46	57	52	49	46	44	
			0.56	1.0	67	61	56	53	66	60	56	53	64	59	55	52	62	58	55	52	51	
				1.25	71	66	61	58	70	65	61	58	68	64	60	58	66	63	60	57	56	
下方投影面積		cm ²		1.5	74	69	65	62	73	68	65	62	71	67	64	61	69	66	63	61	59	
			等価発光面積	cm ²	2.0	77	73	70	67	76	72	70	67	74	71	69	66	72	70	68	66	64
取付高さ	器具間隔最大限			2.5	79	76	73	71	78	75	73	70	76	74	72	70	74	72	70	69	67	
	横方向 (A)		縦方向 (B)		3.0	80	78	75	73	79	77	75	73	78	75	73	72	76	74	72	71	69
H m	1.23 H m		1.23 H m		4.0	82	80	78	76	81	79	77	76	79	78	76	75	77	76	75	74	72
					5.0	83	81	80	78	82	80	79	78	80	79	78	76	78	77	76	75	73
					7.0	84	83	82	81	83	82	81	80	81	80	79	79	80	79	78	77	75
					10.0	85	84	83	82	84	83	82	82	82	81	81	80	80	80	79	79	77

