

屋内照明器具特性

品番 (品名)	XF X4 4 0 AED														
光源	LED6500_85_3860 x1 3860.0 1 m														
管理番号	K0192144(0)D 1														
BZ分類	BZ5														

器具効率	100 %	天井	80 %				70 %				50 %				30 %				0 %		
			反射率	壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %
				床	10 %				10 %				10 %				10 %				0 %
上方光束	4 %	室指数	照明率 (X0.01)																ZCM		
下方光束	96 %																				
保守率	良 中 否	0.83	0.6	5.6	4.3	3.5	3.0	5.4	4.2	3.5	3.0	5.1	4.1	3.4	2.9	4.9	4.0	3.4	2.9	2.7	
		0.81	0.8	6.5	5.4	4.6	4.0	6.4	5.3	4.5	3.9	6.0	5.1	4.4	3.9	5.7	4.9	4.3	3.8	3.6	
		0.77	1.0	7.2	6.1	5.3	4.7	7.0	6.0	5.2	4.7	6.6	5.8	5.1	4.6	6.3	5.6	5.0	4.5	4.2	
			1.25	7.8	6.8	6.0	5.4	7.6	6.6	5.9	5.4	7.2	6.4	5.8	5.3	6.9	6.2	5.6	5.2	4.9	
下方投影面積	c m ²	1.5	8.2	7.2	6.5	6.0	8.0	7.1	6.4	5.9	7.6	6.9	6.3	5.8	7.2	6.6	6.1	5.7	5.4		
		2.0	8.7	7.9	7.3	6.8	8.5	7.8	7.2	6.7	8.1	7.5	7.0	6.6	7.8	7.3	6.8	6.5	6.1		
取付高さ	器具間隔最大限		2.5	9.1	8.4	7.8	7.3	8.9	8.3	7.7	7.3	8.5	8.0	7.5	7.1	8.1	7.7	7.3	7.0	6.6	
	横方向 (A)	縦方向 (B)	3.0	9.3	8.7	8.2	7.8	9.1	8.6	8.1	7.7	8.7	8.3	7.9	7.5	8.4	8.0	7.7	7.4	7.0	
1.5m	1.96 m	2.11 m	4.0	9.6	9.2	8.7	8.4	9.5	9.0	8.6	8.3	9.1	8.7	8.4	8.1	8.7	8.4	8.1	7.9	7.5	
2	2.58	2.64	5.0	9.8	9.4	9.1	8.7	9.7	9.3	8.9	8.6	9.3	9.0	8.7	8.4	8.9	8.7	8.4	8.2	7.8	
2.5	3.21	3.2	7.0	10.1	9.8	9.5	9.2	9.9	9.6	9.3	9.1	9.5	9.3	9.1	8.9	9.2	9.0	8.8	8.6	8.3	
3	3.84	3.77	10.0	10.3	10.0	9.8	9.6	10.1	9.9	9.7	9.5	9.7	9.6	9.4	9.2	9.4	9.3	9.1	9.0	8.6	

