

屋内照明器具特性	
品番 (品名)	XAS1002
光源	LLD2000CU1 x1 566.0 lm
管理番号	K0178921 (0) DR 1
BZ分類	BZ4

器具効率		92 %	反射率	天井	80 %					70 %					50 %					30 %					0 %
				壁	70	50	30	10	70	50	30	10	70	50	30	10	70	50	30	10	0 %				
				床	10 %					10 %					10 %					10 %					0 %
上方光束 下方光束		0 % 92 %	室指数	照明率 (X0.01) ZCM																					
保守率		良 中 否	0.67	0.6	54	43	36	32	53	43	36	31	51	42	36	31	49	41	35	31	29				
			0.63	0.8	64	54	47	42	62	53	46	42	60	52	46	41	58	50	45	41	39				
			0.56	1.0	70	61	54	49	68	60	54	49	66	58	53	48	63	57	52	48	46				
			1.25	75	67	61	56	74	66	60	56	71	65	59	55	69	63	59	55	53					
下方投影面積 等価発光面積		cm ² cm ²	1.5	79	71	66	61	77	71	65	61	75	69	64	60	72	67	63	60	58					
			2.0	84	78	73	69	82	77	72	68	80	75	71	68	77	73	70	67	65					
取付 高さ	器具間隔最大限		2.5	87	82	77	74	85	81	77	73	83	79	75	72	80	77	74	71	69					
	横方向 (A) 縦方向 (B)		3.0	89	84	81	77	88	83	80	77	85	82	78	76	83	80	77	75	72					
H m	1.29 H m	1.29 H m	4.0	92	88	85	82	90	87	84	82	88	85	83	80	85	83	81	79	77					
			5.0	93	90	88	85	92	89	87	85	89	87	85	83	87	85	84	82	79					
			7.0	95	93	91	89	94	92	90	88	91	90	88	87	89	88	86	85	83					
			10.0	96	95	93	92	95	94	92	91	93	92	90	89	91	90	89	88	85					

