

屋内照明器具特性

| | | | | | | | | | | | | | | | | |
|---------|------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 品番 (品名) | XF X4 1 0 ANN | | | | | | | | | | | | | | | |
| 光源 | LED5000_85_1940 x1 1940.0 lm | | | | | | | | | | | | | | | |
| 管理番号 | K0192144(0)D 1 | | | | | | | | | | | | | | | |
| BZ分類 | BZ5 | | | | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | | |
|--------|------------------|---------|--------------|------|------|-----|------|------|------|-----|------|-----|------|-----|------|-----|------|-----|-----|-----|-----|
| 器具効率 | 100 % | 天井 | 80 % | | | | 70 % | | | | 50 % | | | | 30 % | | | | 0 % | | |
| | | | 反射率 | 壁 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 0 % |
| | | | | 床 | 10 % | | | | 10 % | | | | 10 % | | | | 10 % | | | | 0 % |
| 上方光束 | 4 % | 室指数 | 照明率 (X0.01) | | | | | | | | | | | | | | | | ZCM | | |
| 下方光束 | 96 % | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 中 否 | 0.83 | 0.6 | 5.6 | 4.3 | 3.5 | 3.0 | 5.4 | 4.2 | 3.5 | 3.0 | 5.1 | 4.1 | 3.4 | 2.9 | 4.9 | 4.0 | 3.4 | 2.9 | 2.7 | |
| | | 0.81 | 0.8 | 6.5 | 5.4 | 4.6 | 4.0 | 6.4 | 5.3 | 4.5 | 3.9 | 6.0 | 5.1 | 4.4 | 3.9 | 5.7 | 4.9 | 4.3 | 3.8 | 3.6 | |
| | | 0.77 | 1.0 | 7.2 | 6.1 | 5.3 | 4.7 | 7.0 | 6.0 | 5.2 | 4.7 | 6.6 | 5.8 | 5.1 | 4.6 | 6.3 | 5.6 | 5.0 | 4.5 | 4.2 | |
| | | | 1.25 | 7.8 | 6.8 | 6.0 | 5.4 | 7.6 | 6.6 | 5.9 | 5.4 | 7.2 | 6.4 | 5.8 | 5.3 | 6.9 | 6.2 | 5.6 | 5.2 | 4.9 | |
| 下方投影面積 | c m ² | 1.5 | 8.2 | 7.2 | 6.5 | 6.0 | 8.0 | 7.1 | 6.4 | 5.9 | 7.6 | 6.9 | 6.3 | 5.8 | 7.2 | 6.6 | 6.1 | 5.7 | 5.4 | | |
| | | 2.0 | 8.7 | 7.9 | 7.3 | 6.8 | 8.5 | 7.8 | 7.2 | 6.7 | 8.1 | 7.5 | 7.0 | 6.6 | 7.8 | 7.3 | 6.8 | 6.5 | 6.1 | | |
| 取付高さ | 器具間隔最大限 | | 2.5 | 9.1 | 8.4 | 7.8 | 7.3 | 8.9 | 8.3 | 7.7 | 7.3 | 8.5 | 8.0 | 7.5 | 7.1 | 8.1 | 7.7 | 7.3 | 7.0 | 6.6 | |
| | 横方向 (A) | 縦方向 (B) | 3.0 | 9.3 | 8.7 | 8.2 | 7.8 | 9.1 | 8.6 | 8.1 | 7.7 | 8.7 | 8.3 | 7.9 | 7.5 | 8.4 | 8.0 | 7.7 | 7.4 | 7.0 | |
| 1.5m | 1.96 m | 2.11 m | 4.0 | 9.6 | 9.2 | 8.7 | 8.4 | 9.5 | 9.0 | 8.6 | 8.3 | 9.1 | 8.7 | 8.4 | 8.1 | 8.7 | 8.4 | 8.1 | 7.9 | 7.5 | |
| 2 | 2.58 | 2.64 | 5.0 | 9.8 | 9.4 | 9.1 | 8.7 | 9.7 | 9.3 | 8.9 | 8.6 | 9.3 | 9.0 | 8.7 | 8.4 | 8.9 | 8.7 | 8.4 | 8.2 | 7.8 | |
| 2.5 | 3.21 | 3.2 | 7.0 | 10.1 | 9.8 | 9.5 | 9.2 | 9.9 | 9.6 | 9.3 | 9.1 | 9.5 | 9.3 | 9.1 | 8.9 | 9.2 | 9.0 | 8.8 | 8.6 | 8.3 | |
| 3 | 3.84 | 3.77 | 10.0 | 10.3 | 10.0 | 9.8 | 9.6 | 10.1 | 9.9 | 9.7 | 9.5 | 9.7 | 9.6 | 9.4 | 9.2 | 9.4 | 9.3 | 9.1 | 9.0 | 8.6 | |

