

屋内照明器具特性	
品番 (品名)	X F L 3 2 6 K L
光源	LDL40S. N / 14 / 26 (2 6 0 0 A) × 2 2 6 0 0 . 0 l m
管理番号	K 0 1 2 6 7 7 0 (5) D R 1
B Z 分類	B Z 4 / 0 . 7 / B Z 3 / 3 . 5 / B Z 4

器具効率			7 4 %		反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
						壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
						床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
						照明率 (X 0 . 0 1) Z C M																	
保守率			良 中 否	0 . 7 7	0 . 6	4 6	3 8	3 2	2 9	4 5	3 7	3 2	2 9	4 3	3 6	3 2	2 9	4 2	3 6	3 2	2 8	2 7	
				0 . 7 2	0 . 8	5 3	4 6	4 0	3 7	5 2	4 5	4 0	3 7	5 0	4 4	4 0	3 6	4 9	4 3	3 9	3 6	3 5	
				0 . 6 8	1 . 0	5 8	5 1	4 6	4 2	5 7	5 0	4 6	4 2	5 5	4 9	4 5	4 2	5 3	4 8	4 5	4 2	4 0	
					1 . 2 5	6 2	5 6	5 1	4 8	6 1	5 5	5 1	4 7	5 9	5 4	5 0	4 7	5 7	5 3	4 9	4 7	4 5	
下方投影面積			c m ²	1 . 5	6 5	5 9	5 5	5 1	6 4	5 9	5 5	5 1	6 2	5 7	5 4	5 1	6 0	5 6	5 3	5 0	4 9		
				等価発光面積	c m ²	2 . 0	6 9	6 4	6 0	5 7	6 8	6 3	6 0	5 7	6 5	6 2	5 9	5 6	6 4	6 0	5 8	5 6	5 4
取付 高さ	器具間隔最大限				2 . 5	7 1	6 7	6 4	6 1	7 0	6 6	6 3	6 0	6 8	6 5	6 2	6 0	6 6	6 3	6 1	5 9	5 7	
	横方向 (A)		縦方向 (B)		3 . 0	7 2	6 9	6 6	6 4	7 1	6 8	6 5	6 3	6 9	6 7	6 4	6 2	6 7	6 5	6 3	6 1	6 0	
1 . 5m	1 . 8 1 m	1 . 9 8 m		4 . 0	7 4	7 2	6 9	6 7	7 3	7 1	6 9	6 7	7 1	6 9	6 7	6 6	7 0	6 8	6 6	6 5	6 3		
2	2 . 3 9	2 . 4 7		5 . 0	7 6	7 3	7 1	7 0	7 5	7 3	7 1	6 9	7 3	7 1	6 9	6 8	7 1	6 9	6 8	6 7	6 5		
2 . 5	2 . 9 7	2 . 9 8		7 . 0	7 7	7 5	7 4	7 2	7 6	7 4	7 3	7 2	7 4	7 3	7 2	7 1	7 2	7 1	7 0	6 9	6 7		
3	3 . 5 5	3 . 5		1 0 . 0	7 8	7 7	7 6	7 5	7 7	7 6	7 5	7 4	7 5	7 4	7 3	7 3	7 3	7 3	7 2	7 1	6 9		

