

屋内照明器具特性	
品番 (品名)	X F L 3 2 6 E X
光源	LDL40S. N/ 14/ 26 (2 6 0 0 A) × 2 2 6 0 0 . 0 l m
管理番号	K 0 1 2 6 5 0 1 (3) D B 1
B Z 分類	B Z 3 / 0 . 9 / B Z 2

器具効率		7 3 %	反射率	天井	8 0 %				7 0 %				5 0 %				3 0 %				0 %
				壁	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	7 0	5 0	3 0	1 0	0 %
上方光束		0 %		床	1 0 %				1 0 %				1 0 %				1 0 %				0 %
下方光束		7 3 %		室指数	照明率 (X 0 . 0 1)																Z C M
保守率		良 中 否	0 . 8 1	0 . 6	4 5	3 7	3 2	2 9	4 4	3 7	3 2	2 8	4 3	3 6	3 2	2 8	4 1	3 5	3 1	2 8	2 7
			0 . 7 7	0 . 8	5 4	4 7	4 3	3 9	5 3	4 7	4 2	3 9	5 2	4 6	4 2	3 9	5 0	4 5	4 1	3 9	3 7
			0 . 6 8	1 . 0	6 0	5 4	4 9	4 6	5 9	5 3	4 9	4 6	5 7	5 2	4 8	4 6	5 5	5 1	4 8	4 5	4 4
				1 . 2 5	6 4	5 9	5 5	5 2	6 3	5 8	5 4	5 2	6 1	5 7	5 4	5 1	5 9	5 6	5 3	5 1	4 9
下方投影面積		c m ²	1 . 5	6 6	6 2	5 8	5 5	6 5	6 1	5 8	5 5	6 4	6 0	5 7	5 5	6 2	5 9	5 6	5 4	5 3	
等価発光面積		c m ²	2 . 0	7 0	6 6	6 3	6 1	6 9	6 5	6 3	6 0	6 7	6 4	6 2	6 0	6 5	6 3	6 1	5 9	5 8	
取付 高さ	器具間隔最大限		2 . 5	7 2	6 9	6 6	6 4	7 1	6 8	6 6	6 4	6 9	6 7	6 5	6 3	6 7	6 5	6 4	6 2	6 0	
	横方向 (A)	縦方向 (B)	3 . 0	7 3	7 0	6 8	6 6	7 2	7 0	6 8	6 6	7 0	6 8	6 6	6 5	6 9	6 7	6 5	6 4	6 2	
1 . 5m	2 . 7 3 m	2 . 0 9 m	4 . 0	7 5	7 3	7 1	6 9	7 4	7 2	7 0	6 9	7 2	7 0	6 9	6 8	7 0	6 9	6 8	6 7	6 5	
2	3 . 6 4	2 . 6 4	5 . 0	7 5	7 4	7 2	7 1	7 5	7 3	7 2	7 0	7 3	7 2	7 0	6 9	7 1	7 0	6 9	6 8	6 6	
2 . 5	4 . 5 6	3 . 2 1	7 . 0	7 7	7 5	7 4	7 3	7 6	7 5	7 3	7 3	7 4	7 3	7 2	7 1	7 2	7 2	7 1	7 0	6 8	
3	5 . 4 7	3 . 7 8	1 0 . 0	7 7	7 6	7 6	7 5	7 6	7 6	7 5	7 4	7 5	7 4	7 3	7 3	7 3	7 3	7 2	7 2	7 0	

