

# 屋内照明器具特性

品番 (品名) S L B 1 5 7 8 2 + S L K 2 2 0 1 3 + S L K 2 9 0

光源 L L D 3 4 1 1 L C B 1 × 1 7 0 0 . 0 l m

管理番号 K 0 1 9 3 6 8 4 ( 0 ) D B 1

B Z 分類 B Z 1

| 器具効率   |          | 98 %             | 反射率  | 天井            | 80 % |     |     |     | 70 % |    |    |    | 50 % |    |    |    | 30 % |    |    |    | 0 % |       |
|--------|----------|------------------|------|---------------|------|-----|-----|-----|------|----|----|----|------|----|----|----|------|----|----|----|-----|-------|
|        |          |                  |      | 壁             | 70   | 50  | 30  | 10  | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 70   | 50 | 30 | 10 | 0 % |       |
|        |          |                  |      | 床             | 10 % |     |     |     | 10 % |    |    |    | 10 % |    |    |    | 10 % |    |    |    | 0 % |       |
| 上方光束   |          | 7 %              | 室指数  | 照明率 ( X0.01 ) |      |     |     |     |      |    |    |    |      |    |    |    |      |    |    |    |     | Z C M |
| 下方光束   |          | 91 %             |      |               |      |     |     |     |      |    |    |    |      |    |    |    |      |    |    |    |     |       |
| 保守率    |          | 良                | 0.63 | 0.6           | 83   | 77  | 74  | 72  | 82   | 77 | 74 | 71 | 80   | 76 | 73 | 71 | 78   | 75 | 72 | 70 | 69  |       |
|        |          | 中                | 0.6  | 0.8           | 87   | 82  | 79  | 76  | 86   | 81 | 78 | 76 | 84   | 80 | 77 | 75 | 82   | 79 | 76 | 74 | 73  |       |
|        |          | 否                | 0.56 | 1.0           | 90   | 85  | 82  | 80  | 89   | 84 | 81 | 79 | 86   | 83 | 80 | 78 | 84   | 81 | 79 | 77 | 75  |       |
| 下方投影面積 |          | c m <sup>2</sup> |      | 1.25          | 92   | 88  | 85  | 83  | 91   | 87 | 84 | 82 | 88   | 85 | 83 | 81 | 86   | 83 | 81 | 80 | 77  |       |
|        |          |                  |      | 1.5           | 94   | 90  | 87  | 85  | 93   | 89 | 86 | 84 | 90   | 87 | 85 | 83 | 87   | 85 | 83 | 81 | 79  |       |
| 等価発光面積 |          | c m <sup>2</sup> |      | 2.0           | 96   | 93  | 90  | 88  | 95   | 92 | 89 | 87 | 92   | 89 | 87 | 86 | 89   | 87 | 85 | 84 | 81  |       |
|        |          |                  |      | 2.5           | 98   | 95  | 93  | 90  | 96   | 94 | 91 | 89 | 93   | 91 | 89 | 88 | 90   | 88 | 87 | 86 | 82  |       |
| 取付高さ   | 器具間隔最大限  |                  | 3.0  | 99            | 96   | 94  | 92  | 97  | 95   | 93 | 91 | 94 | 92   | 90 | 89 | 91 | 89   | 88 | 87 | 83 |     |       |
| H m    | 0.75 H m | 0.75 H m         | 4.0  | 100           | 98   | 96  | 94  | 98  | 96   | 95 | 93 | 95 | 93   | 92 | 91 | 92 | 91   | 89 | 89 | 85 |     |       |
|        |          |                  | 5.0  | 101           | 99   | 97  | 96  | 99  | 97   | 96 | 95 | 96 | 94   | 93 | 92 | 92 | 91   | 90 | 90 | 86 |     |       |
|        |          |                  | 7.0  | 102           | 100  | 99  | 98  | 100 | 99   | 98 | 96 | 96 | 95   | 95 | 94 | 93 | 92   | 92 | 91 | 87 |     |       |
|        |          |                  | 10.0 | 102           | 101  | 100 | 100 | 101 | 100  | 99 | 98 | 97 | 96   | 96 | 95 | 94 | 93   | 93 | 92 | 88 |     |       |

配光曲線

ランプ光束1000lm

— 管軸に垂直 (A)  
--- 管軸に平行 (B)

直射水平面照度

ランプ光束1000lm

